

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL
ELECTROLOGGING REPORT

Ref No:- 444

Date:- 24-12-2022

NAME OF SITE

Gram Panchayat- Baura

BLOCK- Samrer

DISTT- Budaun

NAME OF AGENCY

M/s PNC-SPML-JV
Badaun



GROUND WATER SURVEY CONSULTANCY
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy

Agra

REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- BAURA, BLOCK- SAMRER, DISTT- BUDAUN
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 130 mtrs. depth. and Logged depth 130 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Badaun.

On the request of M/S PNC-SPML-JV, Badaun. a Geophysical well Logging is conduct at above bore hole using IGIS Well Logger on 24.Dec.2022.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 15	10	Fine sand	
3.	15 - 18	3	Clay	
4.	18 - 30	12	Sand & kankar	
5.	30 - 35	5	Clay kankar	
6.	35 - 63*	28	Medium sand	Med to Good
7.	63 - 67	4	Clay kankar	
8.	67 - 79*	12	Medium sand	Med to Good
9.	79 - 83	4	Clay kankar	
10.	83 - 104*	21	Medium sand	Med to Good
11.	104 - 115	11	Clay kankar	
12.	115 - 122*	7	Medium sand	Med to Good
13.	122 - 125	3	Clay kankar	
14.	125 - 127*	2	Medium sand	Med to Good
15.	127 - 130	3	Clay kankar	

Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium to Good.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist

WTG
/PR/

Ground Water Survey Consultancy

Sheet 1
 N/E SW
 NW/SE
 LAT
 Logging Details
 Date: 10/10/2011
 Time: 10:30 AM
 Location: ...
 Operator: ...
 Figure 1: The
 IGS/S/2011-22
 Scale: 1 cm = 10 m
 Diagram 2
 Ground water Survey
 Consultancy - Agri
 India

