



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date...18/02/2024.....

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency..... N.K.V. Industries..... Mend..... Awt.....
 Village..... Kamoria..... Block..... Nilak.....
 District..... Rampur..... Logging Depth..... 150mtr.....
 Drilling Depth..... 150mtr..... Water Level..... 8mtr.....

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 12	clay Kankar	
3	12 - 18	Fine Sand	
4	18 - 32	clay Kankar	
5	32 - 45	medium Sand	medium
6	45 - 50	clay Kankar	
7	50 - 55*	medium Sand	medium
8	55 - 65	clay Kankar	
9	65 - 84*	medium Sand	medium
10	84 - 89	clay Kankar	
11	89 - 105*	medium Sand	medium
12	105 - 111	clay Kankar	
13	111 - 115*	Fine to med. Sand	medium
14	115 - 120	clay Kankar	
15	120 - 131*	medium Sand	medium
16	131 - 135	clay Kankar	
17	135 - 143*	medium Sand	medium
18	143 - 150	clay Kankar	
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

VIS
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.