



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date..10/03/2024.....

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency..... N.K. Infrastructure Mohd.: Anif.....
 Village..... Suhawa..... Block..... Shahabad.....
 District..... Rampur..... Logging Depth..... 140 mtr.....
 Drilling Depth..... 140 mtr..... Water Level..... 12 mtr.....

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	Dry Sand	
3	10 - 32	Clay Konkaz	
4	32 - 38	Fine to med. Sand	medium
5	38 - 45	Clay Konkaz	
6	45 - 55*	medium Sand	medium
7	55 - 60	Clay Konkaz	
8	60 - 78*	medium Sand	medium
9	78 - 85	Clay Konkaz	
10	85 - 95*	medium Sand	medium
11	95 - 105	Clay Konkaz	
12	105 - 110*	medium Sand	medium
13	110 - 115	Clay Konkaz	
14	115 - 124	Fine Sand	medium
15	124 - 127	Clay Konkaz	
16	127 - 140	Fine Sand	medium
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

V.K.P.
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.