



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date...20/11/2023.....

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency.....M.K.V. Infrastructure.....Mehd.....Araul.....
 Village.....Madyan.....Shan.....Block.....Shahabad.....
 District.....Rampur.....Logging Depth.....140mtr.....
 Drilling Depth.....140mtr.....Water Level.....8mtr.....

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 20	Fine to med. Sand	
3	20 - 33	clay Kankar	
4	33 - 50	medium Sand	medium
5	50 - 55	clay Kankar	
6	55 - 62*	medium Sand	medium
7	62 - 67	clay Kankar	
8	67 - 85*	medium Sand	medium
9	85 - 95	clay Kankar	
10	95 - 110*	Fine to med. Sand	medium
11	110 - 115	clay Kankar	
12	115 - 134*	Fine to med. Sand & clay	medium
13	134 - 140	clay Kankar	
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

[Signature]
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.