



FIELD TEST REPORT

Static W/L 7.77 m

Taste of water Salwat

Date of Test 5-3-09

Time	Discharge in L.P.M.	NWL in Mts	RWL in Mts	Depression in Mts	SAND CONTENTS IN P.P.M.						Recommendations
					Starting	5 Min.	10 Min	15 M	20M.	30M	
	813	7.77	9.72	1.95	100	Tr.	cl	cl	cl	cl	Recommended discharge <u>800 LPM</u> at <u>1.95 m</u> depression Recommended Pumping plant discharge <u>800 Lpm</u>
	945	7.77	9.85	2.08	150	Tr	Tr	cl	cl	cl	
	1078	7.77	10.13	2.36	200	50	Tr	cl	cl	cl	
	1199	7.77	10.38	2.61	250	100	Tr	cl	cl	cl	
	1309	7.77	10.70	2.93	300	150	50	Tr	cl	cl	

Contractor [Signature]

[Signature]  
J. E.

[Signature]  
A. E.

[Signature]  
E. E.

**VERTICALITY TEST REPORT**

DIA of Disc 238 mm Dia of HOUSING 250 mm DATE OF TEST 5-3-09

Height of Suspension 3 Mtrs

Clear 6 mm

Circle Diagram

DEPTH OF Disc	Observed Deviation				Actual Deviation				
	BGL In MTC	E	W	N	S	E	W	N	S
0	0	0	0	0	0	0	0	0	0
3M	0	1	0	1	0	8	0	8	
6M	0	2	0	1	0	12	0	9	
9M	0	2	0	2	0	14	0	14	
12M	0	2	0	2	0	16	0	16	
15M	0	2	0	3	0	18	0	24	
18M	0	3	0	3	0	27	0	27	
21M	0	4	0	3	0	38	0	30	
24M	0	4	0	3	0	42	0	33	

CLEAR SPACE.....At.....  
.....At.....

**CHEMICAL TEST REPORT**

DATE OF TEST		AGENCY		mg/Lit		mg/Lit	
Colour	Hardness Temp.	Chlorides	Nitrate	Remarks			
Nitrates	Copper	Nitrate	Flouridus				
PH	Iron	Amonia					
Total Solids	Total Alkanity						
Dissolved Solids	Sulphates						
Fixed Solids	Calcium						
Total Hardness (C.Co.)	Megnecium						
Permanent Hardness	Turbidity						

[Signature]  
J. E.

[Signature]  
A. E.

[Signature]  
E. E.