

G.P. : Garhi duska dhari T.W No-02.

Block : Hathras

District : Hathras

Required : 370 LPM


300mm dia Plain Pipe : X
200mm dia Plain Pipe : 76.00
200mm dia Slotted Pipe : 24.00
100 mtr

Water level →

Streta :-

24-30 → 0.6 mtr

38-41 → 0.3 mtr



Note → 47 मी से 50 मी के मध्य cement Sealing करनी है

300mm dia Plain Pipe : X
300X200 mm Reducer : X
200mm dia Plain Pipe : 38.50 mtr
200mm dia Slotted Pipe : 09.00 mtr
Total : 47.50 mtr