

JAL NIGAM YANTRIK KHAND U.P. JAL NIGAM MEERUT

Completion Plan of Tube Well

Name of scheme ...TISAN...W.P.S. SCHEME T.W. NO 1

Spring water level in Mtrs. 18.67

Total No. of tube well provided in the scheme.....TWO NO.....

Size of Bore in M.M. 675 x 550 mm

Number & Location of tube-well executed.....NO 1.....

Date of Completion of T.W. 27/06/16

Name of contractor...M/s...Parkash Brothers Meerut

Depth B.G.L. in Meter	Boring Chart with representation	Stratum	Executed Assembly	ABSTRACT
0 - 15.24		surface clay		1. Drilling Started.....19/05/16.....
15.24 - 21.34		Fine to Med. Sand		2. Drilling Completed...20/05/16.....
21.34 - 24.38		Hard clay		3. Lowering on.....01/06/16.....
24.38 - 29.43		Sandy clay	← 300mm →	4. Drilling Depth.....147.80.....M
29.43 - 33.53		Fine to Med Sand		5. 200 mm dia Housing Pipe.....41.82.....M
33.53 - 39.62		sandy clay		6. 300mm dia Reducer Pipe.....110.....M
39.62 - 48.77		YELLOW F-MED SAND	← 200mm →	7. 200 mm dia Blind Pipe.....60.34.....M
48.77 - 51.81		clay + kankar	21.14	8. 200 mm dia Slotted Pipe.....38.55.....M
51.81 - 60.96		FINE SAND	62.34	9. Discharge by Compressor.....1877.....LPM
60.96 - 67.06		F-Med sand.	68.09	10. Discharge by O.P. Unit.....1300.....LPM
67.06 - 70.10		very fine sand	71.89	11. Remark if any:-
70.10 - 79.25		Fine to Med Sand	77.89	
79.25 - 91.44		YELLOW F-MED SAND	150.3	
		Med Sand	98.99	
91.44 - 100.58		Yellow Fine to Med Sand.	98.99	
100.58 - 112.11		Med Sand.	147.52	
112.11 - 115.62		Med. coarse sand	113.51	
			20.53	
115.62 - 135.09		coarse sand	134.04	
			6.05	
135.09 - 147.80		fine Sand	140.09	

Contractor

J. E.

A. E.

E. E.

Countersigned

YIELD TEST OF TW BY COMPRESSOR

Date of Test		Static W/L						Taste of Water.	
Discharge by V. Notch		Stand Contents In PPM						Remarks	
In cm.	In Lpm	Start	5 Min	10 Min	15 Min	30 Min	60 Min		
22	1877	1200	710	240	50	2	cl.		
Contractor		<i>Robit</i> J. E.			<i>Am</i> A. E.			<i>Or</i> E. E.	

YIELD TEST REPORT BY O.P. UNIT

Size of orifice 6" x 5"		Taste of water Sweet					Date of Test 27/06/16					
Height of water column in orifice tube (c.m.)	Discharge in L.P.M.	SWL in Mts	RWL in Mts	Depression in Mts	SAND CONTENTS IN P. P. M.							Recommendations.
					Starting	5 Min.	10 Min.	15 M.	20 M.	25 M.	30 M.	
8"	1384	10.67	13.07	2.40	50	cl	cl	cl	cl	cl	cl	Recommended discharge ...1300 LPM at 2.40mt depression. Recommended Pumping plant discharge...1300 Lpm.
10"	1487	10.67	13.17	2.50	150	Tr	cl	cl	cl	cl	cl	
15"	1627	10.67	13.27	2.60	200	50	cl	cl	cl	cl	cl	
16"	1872	10.67	13.42	2.75	400	100	Tr	cl	cl	cl	cl	
19"	2027	10.67	13.57	2.90	500	200	50	cl	cl	cl	cl	
Contractor		<i>Robit</i> J. E.			A. E.			<i>Or</i> E. E.				

CHEMICAL TEST REPORT

DATE OF TEST		AGENCY	
Mg/Lit	mg/Lit	mg/Lit	mg/Lit
Colour	Hardness Temp.	Chlorides	Remarks
Nitrates	Copper	Nitride	
PH	Iron	Florides	
Total Solids	Total Alkanity	Amonia	
Dissolved Solids	Sulphates		
Fixed Solids	Calcium		
Total Hardness (CaCo3)	Megnecium		
Permanent Hardness	Turbidity		
Contractor		<i>Robit</i> J. E.	
		A. E.	
		<i>Or</i> E. E.	