


# Berara

## RURAL WATER SUPPLY SCHEME UNDER SWSM-JJM

Date- / /

Actual Strata chart & Assembly Lowered of 300X150 mm Size of Berara, Block-Tiloi  
District-Amethi  
Q=400 LPM,H=



1. Bore Size	=	600 x 500 mm
2. Assembly Size	=	300 x 150 mm
3. Drilling Depth	=	300.000 m
4. Logging Depth	=	290.000 m
5. Date of Logging	=	27.06.2023
6. Date of Lowering	=	05.07.2023

### Logging Report

S.No.	Depth Range (mbgl)	Thickness (m)	Remarks
1.	23-30	07	Good
2.	33-40	07	Good
3.	48-52	04	Good
4.	59-68	09	Good
5.	82-85	03	Moderate

1. 300 mm @ Housing Pipe	=	46.500m
2. 150 mm @ Plain Pipe	=	17.190m
3. 150mm @ Screen Pipe	=	3.000m
4. 300 mm @ Soleted pipe	=	22.000m
5. 300 X150 mm @ Reducer	=	0.200m
<b>A.G.L =</b>		<b>0.500m</b>
<b>B.G.L =</b>		<b>88.890m</b>
<b>Total Lowering =</b>		<b>89.390m</b>