


Haripur

RURAL WATER SUPPLY SCHEME UNDER SWSM-JJM

Date- / /

Actual Strata chart & Assembly Lowered of 300X150 mm Size of Haripur, Block-Bhadar
District-Amethi
Q=400 LPM,H=



1. Bore Size	=	600 x 500 mm
2. Assembly Size	=	300 x 150 mm
3. Drilling Depth	=	400.000 m
4. Logging Depth	=	365.000 m
5. Date of Logging	=	02.03.2023
6. Date of Lowering	=	18.04.2023

Logging Report

S.No.	Depth Range (mbgl)	Thickness (m)	Remarks
1.	22-28	06	Good
2.	30-36	04	Good
3.	40-47	07	Good
4.	295-302	07	Good
5.	309-312	03	Good
6.	330-337	07	Good
7.	345-354	09	Good
8.	357-361	04	Moderate

NOTE

Marginal to salins 63 m bgl to 284 m bgl.

1. 300 mm@ Housing Pipe	=	60.540m
2. 150 mm@ Plain Pipe	=	271.490m
3. 150mm @ Screen Pipe	=	17.850m
4. 300 mm @ Soleted pipe	=	10.000m
5. 300 X150 mm@ Reducer	=	0.200m
A.G.L =		0.500m
B.G.L =		360.080m
Total Lowering =		360.580m