


# OFFICE OF THE EXECUTIVE ENGINEER, CONST. DIVISION (E/M), U.P. JAL


## NIGAM, BAREILLY.

COMPLITION PLAN OF RAMJANPUR TUBEWELL (NEAR IDGAH.) 300MMX200MM SIZE DIST. BADAUN UNDER : NRWSP.

AGENCY: DEPARTMENTAL BY: RC RIG MACHINE 600/27



S.No.	in feet	in meter	STRATA
1	0	4	0.00 1.22 Surface Caly
2	4	28	1.22 8.53 Clay
3	28	110	8.53 33.53 Fine sand
4	110	127	33.53 38.71 Clay Kanker
5	127	167	38.71 50.90 Fine to medium sand. Sand stone
6	167	175	50.90 53.34 Clay
7	175	274	53.34 83.52 Fine to medium sand. Sand stone
8	274	282	83.52 85.95 Clay
9	282	291	85.95 88.70 Fine to medium sand
10	291	322	88.70 98.15 Clay
11	322	339	98.15 103.33 Fine to medium sand, Sand stone
12	339	380	103.33 115.85 Caving Clay
13	380	115.85	<b>Total Drilling depth</b>
1	size of bore 675 mm		47.25 m
2	size of bore 550 mm		68.60 m
3	Drilling depth		115.85 m
4	Housing pipe 350MM		37.17 m
5	Slotted pipe 200MM		38.43 m
6	Plain pipe 200MM		30.68 m
7	Reducer 300MMX200MM		0.16 m
8	Total assembly lower		106.44 m
9	AGL		0.45 m
10	BGL		105.99 m
11	Date of drilling start		22.07.2011
12	Date of drilling complete		30.07.2011
13	Date of lowering complete		31.07.2011



### YIELD TEST OF TW BY 250 PSI COMPRESSOR

Date of Test		S.W.L.		Discharge by V notch in		SAND CONTENTS IN P.P.M					Remark
23.08.2011		9.50 m		Inch	L.P.M.	Starting Min.	5 min	10 min	15 min	20 min	
1	9.5	9.0	5.00	8.5	1814	5000	4000	3000	2500	2000	

### YIELD TEST OF TW BY 2 CUSEC O.P.UNIT

Static W/L		Taste of water		Date of Test		Sounding of T.W.before development		Sounding of T.W.after development		SAND CONTENTS IN P.P.M.		Recommendation
9.50 m		Sweet		14.10.2011		102.80 m		102.10 m				
S. No.	Discharge in inch	in L.P.M.	SWL in Mts.	RWL in Mts.	Depression in Mts.	Starting Min.	5 Min.	10 Min.	15 Min.	20 Min.	25 Min.	30 Min.
1	9.5	2385	9.50	14.50	5.00	600	300	100	Tr	Tr	Tr	Cl
2	9.0	2033	9.50	14.00	4.50	300	Tr	Tr	Tr	Tr	Cl	Cl
3	8.5	1814	9.50	13.60	4.10	Tr	Cl	Cl	Cl	Cl	Cl	Cl

Checked BY: Computer  
 Lowered By: J.E.  
 Developed By Comp. & O.P. Unit: J.E., J.E., A.E., Ex. Engineer

Recommended discharge is 1800 l.p.m. at 4.10mtr. depression.