



ESTD. 2010

# GROUND WATER SURVEY CONSULTANCY

## GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006  
 Mob : 9761169000, 9794625420, Email : gwsc\_agra@yahoo.com


Ref No: ..... Date: 17-09-2023

### GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

#### DETAIL OF WATER BEARING ZONES

Name Of Agency: BVA, Agra  
 Village: BVA, Agra  
 District: Agra  
 Drilling Depth: 120m  
 Block: Agra  
 Logging Depth: 120m  
 Water Level: 24m

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 3	Surface Soil	
2	5 - 25	dry sand	
3	25 - 30	dry sand	
4	30 - 35	fine sand	medium
5	35 - 39	dry sand	
6	39 - 41	fine sand	
7	41 - 55	dry sand	med. to moderately
8	55 - 65	sand & gravel	
9	65 - 100	dry gravel	moderately saline
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

*[Signature]*  
 Geophysicist

Specializations In

- Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
- Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.