

S.W.L. 6.80 M. Taste of Water SWEET V-Notch/Office 200X150mm Date of test 20-5-2011

Recommended 1800 LPM. discharge at 4.00 mts depression J.E. A.E.

DIA OF Disc TOTAL HOUSING DATE OF TEST

Circla diagram

CLEAR SPACE At
..... At
..... At

REF :- H. M. 871 DATED 25-5-2011

1. TURBIDITY.....	NTU 1.8	10. MAGNESIUM (as mg) mgl. 18.40
2. PH	8.15	11. IRON (as Fe) mgl. 0.15
3. TOTAL DISSOLVED SOLIDS mgl.	520	
4. TOTAL HARDNESS (as ca co3) mgl.	188	
5. CHLORIDES (as CL) mgl.	120	
6. SULPHATES (as So4) mgl.	35	
7. FLUORIDES (as F) mgl.	0.4	
8. NITRATES (as No3) mgl.	3	
9. CALCIUM (as Ca) mgl.	44.80	