

YIELD TEST REPORT

S.W.L. 6.00M Taste of Water SWEET..... V - Notch/Office 150 X 125mm Date of test 07-05-2010

[illegible]

Recommended 1800 LPM. discharge at 3.90 mts depression


A. E.

VERTICALITY TEST REPORT

DIA OF Disc TOTAL HOUSING DATE OF TEST

Height of Suspension ...

Circla diagram

[illegible]

CLEAR SPACE At
..... At
..... At

AGENCY

C120 MLD WATER TREATMENT

LAB, PRATAP VIHAR, GHAZIABAD.

WATER TEST RESULTS

REF :- H. M. 735 DATED 17-05-2010

1. TURBIDITY.....	0.6
2. PH	7.8
3. TOTAL DISSOLVED SOLIDS mgl.	3.80
4. TOTAL HARDNESS (as ca co ₃) mgl.	2.28
5. CHLORIDES (as CL) mgl.	30
6. SULPHATES (as So ₄) mgl.	52
7. FLUORIDES (as F) mgl.	N.D.
8. NITRATES (as No ₃) mgl.	4
9. CALCIUM (as Ca) mgl.	45

10. MAGNESIUM (as mg) mgl. 28
11. IRON (as Fe) mgl. 0.07

Draught's Signature

J. E. C.

A. E.

Executive Engineer