

**JAL NIGAM YANTRIK KHAND
U.P. JAL NIGAM MEERUT
Completion Plan of Tube Well**

Name of Scheme ... Hasanpur, 10/s... Scheme... Shamli Spring water level Inc. Mtrs.
 Total No. of Tube well Provided in the Scheme... 04 Size of Bore in M.M.
 Number & Location of tube-well Executed... 02 (Zone-2) Hasanpur, 0.41F Dabit comlubond of two.....
 Name of Contractor... M/S. S.S. Enterprises, Meerut. Date of Completion of T.W.

Depth B. GL Meter	Boring Chart with representation	Stratum	Executed Assembly	ABSTRACT
			← 200 MM →	
0 - 12.54 Mtr		Surface clay	6.13	1. Drilling Started.....
			6.13	2. Drilling Completed.....
			6.13	3. Lowering on.....
12.54 Mtr - 20.50 Mtr		Fine Sand	6.13	4. Drilling Depth..... M
			6.13	5.Dia Housing Pipe..... M
			6.13	6.Dia Reducer..... M
20.50 Mtr - 42.30 Mtr		Clay	6.13	7.Dia Blind Pipe..... M
			6.13	8.Dia Slotted Pipe..... M
42.30 Mtr - 52.80 Mtr		Medium Sand	6.13	
52.80 Mtr - 65.10 Mtr		Clay	6.13	
65.10 Mtr - 71.55 Mtr		Medium Sand	4.50	
71.55 Mtr - 77.50 Mtr		Clay	6.13	9. Discharge by Compressor.....
77.50 Mtr - 83.85 Mtr		Medium Sand	6.13	10. Discharge by O.P. Unit.....
			6.05	11. Remark if any:-
			6.05	
			6.05	
83.85 Mtr - 108.25 Mtr		Clay	6.05	
			6.05	
108.25 Mtr - 120.35 Mtr		Very fine Sand	6.05	
			6.05	
120.35 Mtr - 138.60 Mtr		Clay	1.35	
138.60 Mtr - 145.10 Mtr		Medium Sand	3.20	
145.10 Mtr - 147.60 Mtr		Clay	2.10	
147.60 Mtr - 154.05 Mtr		Medium Sand	6.13	
			2.85	
154.05 Mtr - 168.90 Mtr		Clay	6.13	
			6.30	

As Executed Countersigned

Contractor *[Signature]* A. E. A. E. E. E.

YIELD TEST OF BY COMPRESSOR

Date of Test		Static W/L				Taste of Water.		Remarks
Discharge by V. Notch		Sand Contents In PPM						
In cm.	In Lpm	Start	5 Min	10 Min	15 Min	30 Min	60 Min	