

JAL NIGAM YANTRIK KHAND U.P. JAL NIGAM MEERUT Completion Plan of Tube Well

Name of Scheme Lisath. Wals. Scheme Spring water level inc. Mtrs.

Total No. of Tube well Provided in the Scheme 04 Size of Bore in M.M.

Number & Location of tube-well Executed D.1. (Zone-1) D.H.T. (Campy) Dabit comlubond of two

Name of Contractor M.C. S.C. Enterprises, Meerut Date of Completion of T.W.

Depth B. GL Meter	Boring Chart with repretation	Stratum	Executed Assembly	ABSTRACT
0 - 21.34 Mts		Surface clay	200mm 6.09 6.09 6.09 6.09 6.09 6.10 6.08 6.08 6.10 6.08	1. Drilling Started..... 2. Drilling Completed..... 3. Lowering on..... 4. Drilling Depth.....M 5. Dia Housing Pipe.....M 6. Dia Reducer.....M 7. Dia Blind Pipe.....M 8. Dia Slotted Pipe.....M
21.34 Mts - 51.82 Mts	51.82 Mts	Fine Medium sand	6.08 6.10 6.08	9. Discharge by Compressor..... 10. Discharge by O.P. Unit..... 11. Remark if any..
51.82 Mts - 67.80 Mts	67.80 Mts	clay	0.15 6.10 1.50 6.05 6.07 2.80 4.59 4.08 6.08 6.10 6.10 6.09 6.09 3.59 6.11 3.00 3.25 6.15 6.12 5.33	60.34 68.14M 82.24 86.85 90.91
67.80 Mts - 82.40 Mts	82.40 Mts	Medium sand		
82.40 Mts - 86.70 Mts	86.70 Mts	clay		
86.70 Mts - 90.95 Mts	90.95 Mts	Medium sand		
90.95 Mts - 124.80 Mts	124.80 Mts	clay		
124.80 Mts - 134.25 Mts	134.25 Mts	Fine Medium sand		
134.25 Mts - 137.20 Mts	137.20 Mts	clay		
137.20 Mts - 149.80 Mts	149.80 Mts	Medium sand		
149.80 Mts - 160.00 Mts	160.00 Mts	clay	200mm	

As Executed

Countersigned

Contractor

A. E.

E. E.

YIELD TEST OF BY COMPRESSOR

Date of Test Static W/L Taste of Water.

Discharge by V. Nutch		Sand Contents in PPM						Remarks
In cm.	In Lpm	Start	5 Min	10 Min	15 Min	30 Min	60 Min	

Contractor

J. E.

A. E.

E. E.