


JAL NIGAM YANTRIK KHAND U.P. JAL NIGAM MEERUT

Completion Plan of Tube Well

Name of scheme Dixitbagam, wife. Scheme Shanti Spring water level in Mtrs 24.00 MTR
 Total No. of tube well provided in the scheme 01 Size of Bore in M.M. 550x550
 Number & Location of tube-well executed 0:HT: Campus Date of Completion of T.W. 04/06/2020
 Name of contractor M/s. Kailas Kumar Sharma, Meerut

Depth B.G.L. in Meter	Boring Chart with representation	Stratum	Executed Assembly	ABSTRACT
			0.5M	1. Drilling Started <u>15/02/2020</u>
0 - 11.20 MTR		Surface clay	6.00	2. Drilling Completed <u>24/02/2020</u>
11.20 MTR - 19.25 MTR		Very fine Sand	6.00	3. Lowering on <u>26/02/2020</u>
			6.00	4. Drilling Depth <u>135.00</u> M
19.25 MTR - 30.50 MTR		Clay	6.00	5. <u>200</u> mm dia Housing Pipe <u>73.00</u> M
			6.00	6. <u> </u> mm dia Reducer Pipe <u> </u> M
30.50 MTR - 44.20 MTR		Medium Sand	6.00	7. <u>900</u> mm dia Blind Pipe <u>28.70</u> M
			6.00	8. <u>200</u> mm dia Slotted Pipe <u>24.00</u> M
44.00 MTR - 50.10 MTR		Clay	6.00	9. Discharge by Compressor <u> </u> LPM
50.10 MTR - 57.25 MTR		Sandy clay	6.00	10. Discharge by O.P. Unit <u> </u> LPM
57.25 MTR - 72.56 MTR		Clay	6.00	11. Remark if any:-
72.56 MTR - 85.97 MTR		Medium sand	1.50	
			6.00	
			6.00	
85.97 MTR - 102.90 MTR		Clay	6.00	
			3.00	
102.90 MTR - 106.15 MTR		Medium Sand	4.70	
			6.00	
106.15 MTR - 110.60 MTR		Clay	3.00	
110.60 MTR - 120.73 MTR		Medium Sand	6.00	
			6.00	
120.73 MTR - 130.75 MTR		Clay	125.30M	

Countersigned


 Contractor A. E. E. E.