

Lowering of T.W. Assembly at Arda T.W. Basti

Drilling/Lowering - 132/120
 Bore Size - 550x500mm
 S.W.L. - 3.90m

T.W. Assembly Size - 200x150mm
 Recommended Discharge - 600 L.P.M
 D.O.L. - 19/01/21

Logging Report

- 1. 12 - 24 → 12
- 2. 36 - 38 → 2
- 3. 46 - 52 → 6
- 4. 55 - 68 → 13
- 5. 74 - 94 → 20
- 6. 116 - 124 → 8

G1	6.00	0.50m
	6.00	
	6.14	
	6.14	
	6.12	
	6.12	
	6.10	
	6.10	
	6.10	
	6.05	

Strata as per Actual

0 - 10m clay			
10 - 23m M.Sand			
23 - 35m clay			
35 - 38m F.Sand			
38 - 45m clay			
45 - 50m F-to-M.Sand	6.05		
50 - 60m clay	3.02		
60 - 69m F-to-M.Sand			
69 - 73m clay			
73 - 95m F-to-M.Sand			
95 - 115m clay			
115 - 125m V.F.Sand			
125 - 132m clay			

0.15m	60.37m
6.02m	60.52m
8.50m	66.54m
9.07m	75.04m
6.04m	84.11m
6.02m	87.63m
6.02m	93.67m
6.02m	99.69m
AGL (+) 0.50m	
<u>Total</u>	<u>100.19m</u>

(M/S Ujjain Singh) Contractor
 (Sampurnanand) J.C.
 (Babbar Yadav) A-E.
 (Adarsh Verma) E.F.

Important Notes