

Lowering of T.W. Assembly at Adampur T.W. Burti
 Lowering - 132/20
 T.W. Assembly Size - 200x200mm
 Recommended Discharge - 600 L.P.M.


- 550x550mm

- 4 feet

D.O.L. - 30/10/20

ing Report

1-34-20
 2-46-1
 52-65-13
 78-88-10
 110-118-8
 122-130-8



ata as Per Actual

0 - 6m clay
 6 - 9 m M.Sand
 9 - 12 m clay
 12 - 36 m M.Sand
 36 - 40 m clay
 40 - 45 m F.to M.Sand
 45 - 54 m clay
 54 - 66 m F.to M.Sand
 66 - 77 m clay
 77 - 89 m F.to M.Sand
 89 - 107 m clay
 107 - 119 m F.to M.Sand
 119 - 124 m clay
 124 - 129 m F.to M.Sand
 135 m clay

AGL @ 0.50m
 Total 124.05m

OCTOBER
 5 12 19 26
 6 13 20 27
 7 14 21 28
 1 8 15 22 29
 2 9 16 23 30
 3 10 17 24 31
 4 11 18 25

115 Jai Baburash chaurhary) (Sampuranand) (Babban Yadav) (Adarsh Verma)
 Contractor J.E. Searched with Cam