





# M/S VSAIPPL-SMC JV, Ghazipur (U.P.)

Regd. Office-#10, APIIC Building, Type-III, I.E, Prashanth Nagar Kukatpally, Hyderabad-500072

Under Jal Jivan Mission, District- Ghazipur(U.P.)

Test Report of Jayantidaspur GP (Zone-8, TW-1) Tubewell under Arsadpur Jangipur WSS, Block-Jangipur Development By 250 PSI Air Compressor

Size of tube well (mm): 200 X 150 RPM 1300

Static water level (m): 12.00 Discharge by-90 'V' notch (Rectangular)

S. N.	Depth of T/W (m): 113.500		Required Discharge- 300 LPM		Date of testing 04-09-2023				
	Depression		Discharge by 'V' Notch		Sand content in P.P.M.				
	Starting Pressure kg/cm <sup>2</sup>	In mtr.	Inch	LPM	At start	After 5 min	After 10 min	After 15 min	After 20 min
1	8.80	7.00	5 3/4	675	6200	3400	3200	3000	2900
2	7.90	6.00	5 1/2	604	5700	3200	3000	2800	2700
3	4.10	5.00	5	476	5100	2900	2700	2500	2300

Remark- Recommended for further development by O.P. Unit

(.....) Company Repre.  
M/S VSAIPPL-SMC  
JV, Ghazipur (U.P.)

(.....) TPIA

Medhaj Techno Concept Pvt.  
Ltd., Ghazipur

(Abhishek Srivastava)  
Junior Engineer

(Nitish Kumar)  
Assistant Engineer

(Adarsh Verma)  
Executive Engineer

Division Office (E&M), U.P. Jal Nigam(Rural), Varanasi



**M/S VSAIPPL-SMC JV, Ghazipur (U.P)**

<b>Job Code:</b>		<b>Compressor unit</b>	<b>As per DPR:</b>	600 PSI	
<b>Block:</b>	VIRNO	<b>Capacity</b>	<b>As per Site:</b>	250 PSI	
<b>Scheme</b>	ARSADPUR (JANGIPUR ) REORGANISATION WSS	<b>Compressor unit</b>	<b>As per DPR:</b>	60	
<b>GP</b>	JAYANTIDASPUR, ZONE 8	<b>Hours</b>	<b>As per Site:</b>	58:00	
<b>Lowering Depth(mtr):</b>	113.500	<b>Cumm</b>			
<b>Lowering Date :</b>	11-Aug-23	<b>Gravel(cum)</b>	<b>As per DPR:</b>	79.5	
		<b>Cumm</b>			
		<b>Gravel(cum)</b>	<b>As per Site:</b>	76.0 <i>61.46</i>	
<b>SI No</b>	<b>Date</b>	<b>Start Time</b>	<b>End Time</b>	<b>Total Hours</b>	<b>Remarks</b>
1	27-Aug-23	7:29 AM	8:50 AM	1:21	
2		10:00 AM	11:25 AM	1:25	
3		12:00 PM	1:21 PM	1:21	
4		2:00 PM	3:30 PM	1:30	
5		4:00 PM	5:20 PM	1:20	
6	28-Aug-23	8:29 AM	9:54 AM	1:25	
7		10:00 AM	11:15 AM	1:15	
8		1:00 PM	2:30 PM	1:30	
9		4:20 PM	5:50 PM	1:30	
10		6:00 PM	7:30 PM	1:30	
11	29-Aug-23	9:00 AM	10:20 AM	1:20	
12		11:00 AM	12:26 PM	1:26	
13		2:00 PM	3:30 PM	1:30	
14		4:00 PM	5:20 PM	1:20	
15		6:29 PM	7:34 PM	1:05	
16	30-Aug-23	10:00 AM	11:10 AM	1:10	
17		12:00 PM	12:50 PM	0:50	
18		1:30 PM	2:30 PM	1:00	

*Handwritten signatures and initials at the bottom of the page.*



**M/S VSAIPPL-SMC JV, Ghazipur (U.P)**

<b>Job Code:</b>		<b>Compressor unit</b>	<b>As per DPR:</b>	<b>600 PSI</b>	
<b>Block:</b>	VIRNO	<b>Capacity</b>	<b>As per Site:</b>	<b>250 PSI</b>	
<b>Scheme</b>	ARSADPUR (JANGIPUR )	<b>Compressor unit</b>	<b>As per DPR:</b>	<b>60</b>	
<b>GP</b>	REORGANISATION WSS	<b>Hours</b>	<b>As per Site:</b>	<b>58:00</b>	
<b>Lowering Depth(mtr):</b>	<b>113.500</b>	<b>Cumm</b>			
<b>Lowering Date :</b>	<b>11-Aug-23</b>	<b>Gravel(cum)</b>	<b>As per DPR:</b>	<b>79.5</b>	
		<b>Cumm</b>			
		<b>Gravel(cum)</b>	<b>As per Site:</b>	<b>76.0</b> <i>61.46</i>	
<b>SI No</b>	<b>Date</b>	<b>Start Time</b>	<b>End Time</b>	<b>Total Hours</b>	<b>Remarks</b>
19		3:00 PM	4:26 PM	1:26	
20		5:00 PM	6:30 PM	1:30	
21	31-Aug-23	8:00 AM	9:14 AM	1:14	
22		10:10 AM	11:20 AM	1:10	
23		1:30 PM	2:10 PM	0:40	
24		3:20 PM	4:26 PM	1:06	
25		5:30 PM	7:00 PM	1:30	
21		1-Sep-23	8:00 AM	9:14 AM	1:14
22	10:10 AM		11:30 AM	1:20	
23	1:30 PM		2:30 PM	1:00	
24	3:20 PM		4:46 PM	1:26	
25	5:30 PM		6:31 PM	1:01	
11	2-Sep-23	9:00 AM	10:10 AM	1:10	
12		11:00 AM	12:06 PM	1:06	
13		2:00 PM	3:00 PM	1:00	
14		4:00 PM	5:10 PM	1:10	
15		6:29 PM	7:34 PM	1:05	
11		9:00 AM	10:10 AM	1:10	

*Handwritten signatures and initials in blue ink at the bottom of the page.*









# QA Testing Laboratories Pvt. Ltd.

(Govt. Approved Testing Laboratories)

B-76, Sector-64, Gautam Buddha Nagar, Noida-201301 (Uttar Pradesh)

Tel.: +91-120-4133953 • Mobile: +91-8287945370 • E-mail: admin@qatestinglaboratories.com

Website : www.qatestinglaboratories.com

CIN : U51100UP2018PTC108293 • GSTIN : 09AAACQ5609C1ZN

18

JAS-ANZ



M54009131N



An ISO 9001:2015, 14001:2015, 45001:2018 & ISO/IEC 17025:2017 Accredited Laboratory



## TEST CERTIFICATE

(This Certificate is not Valid without Hologram)

Test Report No : QALWT/230925001786  
Sample Name : Borewell Water  
Sample Code : -  
Issued To : VSAIPPL-SMC JV  
District-Ghazipur.

Issue Date : 04/10/2023  
Sample Received On : 25/09/2023  
Reference No : VSAIPPL-SMC/UPJN/23-24/38  
Sampling Date : 25/09/2023  
Sampling Quantity : 2 Ltr.  
Batch No./Lot No. : NA  
Date of Mfg. : NS  
Date of Exp. : NS  
Date of Starting : 25/09/2023  
Date of Completion : 04/10/2023

Sample Submitted By : VSAIPPL-SMC JV

Mfg. By : NA

Sample Description : UP/WT/JAUNPUR/22-23/1167

Location : Distt-Ghazipur B-Virno GP-Jayantidaspur (Zone-8)

S.No.	Test Parameter	Units	Results	Specification as per IS:10500:2012		Test Method
				Acceptable Limit	Permissible Limit	
1	Color	Hazen	1	5 max.	15 max.	IS : 3025 (P-4)
2	Turbidity	NTU	0.4	1 max.	5 max.	IS : 3025 (P-10)
3	pH value at 25°C	-	7.88	6.5-8.5	No Relaxation	IS : 3025 (P-11)
4	Total Hardness as CaCO <sub>3</sub>	mg/l	190	200 max	600 max.	IS : 3025 (P-21)
5	Calcium (as Ca)	mg/l	44.8	75 max	200 max	IS : 3025 (P-40)
6	Iron (as Fe)	mg/l	0.032	1 max	-	IS : 3025 (P-53)
7	Magnesium (as Mg)	mg/l	18.9	30 max	100 max	IS : 3025 (P-46)
8	Chloride (as Cl)	mg/l	24.0	250 max.	1000 max.	IS : 3025 (P-32)
9	Free Residual Chlorine	mg/l	Nil	0.2 max.	1 Max	IS : 3025 (P-26)
10	Sulphates (as SO <sub>4</sub> )	mg/l	8.2	200 max.	400 max.	IS : 3025 (P-24)
11	Total Alkalinity (as CaCO <sub>3</sub> )	mg/l	124	200 max.	600 max.	IS : 3025 (P-23)
12	Fluoride (as F)	mg/l	0.034	1 max.	1.5 max.	IS : 3025 (P-60)
13	Total Dissolved Solid (TDS)	mg/l	455	500 max.	2000 max.	IS : 3025 (P-16)
14	Total Coliform Bacteria	MPN/10 0 ml	Absent	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	IS : 1622
15	E coli	MPN/10 0 ml	Absent	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	IS : 1622

SAMPLE COLLECTED BY US

\*\*\*End of Report\*\*\*

Upendra Kumar  
Technical manager

Authorized By (Sign & Stamp):

Deep Kumar  
Quality Manager

Approved By (Sign & Stamp):

Note: a) This report is not reproduced wholly or in partially and forbidden to be used as an evidence in the court of law and ought not be used in any advertisement media without our special permission in writing. b) The data reported in this TEST CERTIFICATE are valid at the time of and under the stipulated conditions of measurement and the test results are applicable to those items of product which have been tested and do not apply to the other products even though declared to be identical. c) Except by special arrangement, the test items will not be retained by the company not more than one month. d) Report refers to the sample received by M/s QA Testing Laboratories Pvt. Ltd. e) This report is valid for the tested sample only.





Quality Assurance

# QA Testing Laboratories Pvt. Ltd.

(Govt. Approved Testing Laboratories)

B-76, Sector-64, Gautam Buddha Nagar, Noida-201301 (Uttar Pradesh)

Tel.: +91-120-4133953 • Mobile: +91-8287945370 • E-mail: admin@qatestinglaboratories.com

Website : www.qatestinglaboratories.com

CIN : U51100UP2018PTC108293 • GSTIN : 09AAACQ5609C1ZN

IAS-ANZ



M54009131N



An ISO 9001:2015, 14001:2015, 45001:2018 & ISO/IEC 17025:2017 Accredited Laboratory



## TEST CERTIFICATE (This Certificate is not Valid without Hologram)

Test Report No : QAL/WT/230925001786

Issue Date : 04/10/2023

Sample Name : Borewell Water

Sample Received On : 25/09/2023

S.No.	Test Parameter	Units	Results	Specification as per IS:10500:2012		Test Method
				Acceptable Limit	Permissible Limit	
16	Nitrate (as NO <sub>3</sub> )	mg/l	0.34	45 max	No Relaxation	IS : 3025 (P-34)
17	Copper (as Cu)	mg/l	ND	0.05 max	1.5 max	IS : 3025 (P-42)
18	Manganese (as Mn)	mg/l	0.020	0.1 max	0.3 max	IS : 3025 (P-59)
19	Mercury (as Hg)	mg/l	ND	0.001 max	No Relaxation	IS : 3025 (P-48)
20	Cadmium (as Cd)	mg/l	ND	0.003 max	No Relaxation	IS : 3025 (P-41)
21	Selenium (as Se)	mg/l	ND	0.01 max	No Relaxation	IS : 3025 (P-56)
22	Total Arsenic (as As)	mg/l	ND	0.01 max	0.05 max	IS : 3025 (P-37)
23	Lead (as Pb)	mg/l	ND	0.01 max	No Relaxation	IS : 3025 (P-47)
24	Zinc (as Zn)	mg/l	0.022	5 max	15 max	IS : 3025 (P-49)
25	Cobalt	mg/l	ND	-	-	IS : 3025 (P-2)
26	Aluminium (as Al)	mg/l	ND	0.03 max	0.2 max	IS : 3025 (P-55)
27	Boron (as B)	mg/l	0.012	0.5 max	1.0 max	IS : 3025 (P-57)
28	Barium (as Ba)	mg/l	0.014	0.7 max	No Relaxation	IS:13428
29	Silver (as Ag)	mg/l	ND	0.1 max	No Relaxation	IS:13428
30	Molybdenum (as Mo)	mg/l	ND	0.07 max	No Relaxation	IS : 3025 (P-2)
31	Nickel (as Ni)	mg/l	ND	0.02 max	No Relaxation	IS : 3025 (P-54)
32	Total Chromium (as Cr)	mg/l	ND	0.05 max	No Relaxation	IS : 3025 (P-52)
33	Antimony (as Sb)	mg/l	ND	-	-	IS :3025 (P-2)

Note: ND= Not Detected

SAMPLE COLLECTED BY US

\*\*\*End of Report\*\*\*

Upendra Kumar  
Technical manager  
Authorized By (Sign & Stamp):

Upendra Kumar  
Quality Manager  
Approved By (Sign & Stamp):

Note: a) This report is not reproduced wholly or in partially and forbidden to be used as an evidence in the court of law and ought not be used in any advertisement media without our special permission in writing. b) The data reported in this TEST CERTIFICATE are valid at the time of and under the stipulated conditions of measurement and the test results are applicable to those items of product which have been tested and do not apply to the other products even though declared to be identical. c) Except by special arrangement, the test items will not be retained by the company not more than one month. d) Report refers to the sample received by M/s QA Testing Laboratories Pvt. Ltd. e) This report is valid for the tested sample only.



## M/S VSAIPPL-SMC JV, Ghazipur (U.P.)

Regd. Office-#10, APIIC Building, Type-III, I.E, Prashanth Nagar Kukatpally, Hyderabad-500072

Under Jal Jivan Mission, District- Ghazipur(U.P.)

**Yield Test Report Of T.W at Jayantidaspur GP (Zone-8, TW-1) Tubewell under Arsadpur Jangipur WSS,  
Block-Birno by 1 Cusec O.P. Unit**

Size of Ventury      4" X 3"

Column Pipe Lowered:    30.00

Static water level(m): 12.00

Required Discharge(LPM)- 300

Date: 23-09-2023

S.N.	Discharge		Running Water Level (m)	Depression (m)	Sand content in P.P.M.				
	Inch	LPM			At start	After 5 min	After 10 min	After 15 min	After 20 min
1	18.00	674	18.80	6.80	550	300	200	150	100
2	14.50	602	17.70	5.70	300	200	150	100	50
3	5.00	379	15.90	3.90	100	50	Tr	Cl	Cl

**Remark-** Recommended discharge 300 L.P.M. at 3.9 m depression after running 15 minute bypass.



Company Repr.  
M/S VSAIPPL-SMC  
JV, Ghazipur (U.P.)

(.....)  
TPIA

(Abhishek Srivastava)  
Junior Engineer

(Nitish Kumar)  
Assistant Engineer

(Adarsh Verma)  
Executive Engineer

Medhaj Techno Concept Pvt.  
Ltd., Ghazipur

Division Office (E&M), U.P. Jal Nigam(Rural), Varanasi



**M/S VSAIPPL-SMC JV, Ghazipur (U.P)**

<b>Job Code:</b>		<b>Op unit</b>	<b>As per DPR:</b>	<b>1 Cusec</b>	
<b>Block:</b>	VIRNO	<b>Capacity</b>	<b>As per Site:</b>	<b>1 Cusec</b>	
<b>Scheme</b>	ARSADPUR ( JANGIPUR ) REORGAN	<b>Op unit</b>	<b>As per DPR:</b>	100	
<b>GP</b>	JAYANTIDASPUR, ZONE 8 १२०-१	<b>Hours</b>	<b>As per Site:</b>	<b>95:00</b>	
<b>Lowering Depth(mtr):</b>	113.500	<b>Cumm</b>			
<b>Compressor Testing Date</b>	04-09-2023	<b>Gravel(cumt)</b>	<b>As per DPR:</b>	79.5	
		<b>Cumm</b>			
		<b>Gravel(cumt)</b>	<b>As per Site:</b>	61.46	
<b>SI No</b>	<b>Date</b>	<b>Start Time</b>	<b>End Time</b>	<b>Total Hours</b>	<b>Remarks</b>
1	12-09-2023	8:25 AM	9:50 AM	1:25	
2		10:24 AM	11:50 AM	1:26	
3		12:30 PM	1:50 PM	1:20	
4		3:59 PM	5:28 PM	1:29	
5		6:02 PM	7:20 PM	1:18	
6		7:30 PM	8:40 PM	1:10	
7	13-09-2023	8:55 AM	10:16 AM	1:21	
8		10:24 AM	11:54 AM	1:30	
9		12:20 PM	1:50 PM	1:30	
10		3:56 PM	5:26 PM	1:30	
11		6:12 PM	7:30 PM	1:18	
12		7:40 PM	9:10 PM	1:30	
13	14-09-2023	8:45 AM	10:10 AM	1:25	
14		10:44 AM	11:50 AM	1:06	
15		12:50 PM	2:20 PM	1:30	
16		3:46 PM	5:16 PM	1:30	
17		6:02 PM	7:10 PM	1:08	
18		7:50 PM	9:10 PM	1:20	
19	15-09-2023	8:45 AM	9:50 AM	1:05	
20		10:34 AM	11:50 AM	1:16	
21		12:40 PM	1:50 PM	1:10	
22		3:56 PM	5:18 PM	1:22	
23		6:02 PM	7:10 PM	1:08	
24		7:40 PM	8:30 PM	0:50	
25	16-09-2023	8:55 AM	10:16 AM	1:21	
26		10:44 AM	11:55 AM	1:11	
27		12:40 PM	1:50 PM	1:10	
28		3:56 PM	5:26 PM	1:30	


*Jaf*

*Dr. [Signature]*







**M/S VSAIPPL-SMC JV, Ghazipur (U.P)**

<b>Job Code:</b>		<b>Op unit</b>	<b>As per DPR:</b>	<b>1 Cusec</b>	
<b>Block:</b>	VIRNO	<b>Capacity</b>	<b>As per Site:</b>	<b>1 Cusec</b>	
<b>Scheme</b>	ARSADPUR ( JANGIPUR ) REORGAN	<b>Op unit</b>	<b>As per DPR:</b>	100	
<b>GP</b>	JAYANTIDASPUR,ZONE 8	<b>Hours</b>	<b>As per Site:</b>	<b>95:00</b>	
<b>Lowering Depth(mtr):</b>	113.500	<b>Cumm</b>			
<b>Compressor Testing Date</b>	04-09-2023	<b>Gravel(cumt)</b>	<b>As per DPR:</b>	79.5	
		<b>Cumm</b>			
		<b>Gravel(cumt)</b>	<b>As per Site:</b>	61.46	
<b>SI No</b>	<b>Date</b>	<b>Start Time</b>	<b>End Time</b>	<b>Total Hours</b>	<b>Remarks</b>
29	17-09-2023	6:12 PM	7:20 PM	1:08	
30		7:40 PM	9:10 PM	1:30	
31		8:55 AM	10:16 AM	1:21	
32		10:44 AM	11:55 AM	1:11	
33		12:40 PM	2:00 PM	1:20	
34		3:56 PM	5:26 PM	1:30	
35		6:12 PM	7:20 PM	1:08	
36		7:40 PM	9:00 PM	1:20	
37	18-09-2023	8:45 AM	10:00 AM	1:15	
38		10:44 AM	12:14 PM	1:30	
39		12:50 PM	2:10 PM	1:20	
40		3:56 PM	5:08 PM	1:12	
41		6:02 PM	7:10 PM	1:08	
42		7:40 PM	9:00 PM	1:20	
43	19-09-2023	8:45 AM	10:00 AM	1:15	
44		10:44 AM	11:50 AM	1:06	
45		12:40 PM	2:00 PM	1:20	
46		3:56 PM	5:16 PM	1:20	
47		6:12 PM	7:20 PM	1:08	
48		7:40 PM	9:00 PM	1:20	
49	20-09-2023	8:45 AM	10:10 AM	1:25	
50		10:44 AM	11:50 AM	1:06	
51		12:50 PM	2:10 PM	1:20	
52		3:56 PM	5:18 PM	1:22	
53		6:02 PM	7:10 PM	1:08	
54		7:40 PM	9:09 PM	1:29	
55		8:45 AM	10:00 AM	1:15	
56		10:44 AM	11:50 AM	1:06	





### M/S VSAIPPL-SMC JV, Ghazipur (U.P)

<b>Job Code:</b>		<b>Op unit</b>	<b>As per DPR:</b>	<b>1 Cusec</b>	
<b>Block:</b> VIRNO		<b>Capacity</b>	<b>As per Site:</b>	<b>1 Cusec</b>	
<b>Scheme</b> ARSADPUR ( JANGIPUR ) REORGAN		<b>Op unit</b>	<b>As per DPR:</b>	<b>100</b>	
<b>GP</b> JAYANTIDASPUR,ZONE 8		<b>Hours</b>	<b>As per Site:</b>	<b>95:00</b>	
<b>Lowering Depth(mtr):</b> 113.500		<b>Cumm</b>			
<b>Compressor Testing Date</b> 04-09-2023		<b>Gravel(cumt)</b>	<b>As per DPR:</b>	79.5	
		<b>Cumm</b>			
		<b>Gravel(cumt)</b>	<b>As per Site:</b>	61.46	
<b>SI No</b>	<b>Date</b>	<b>Start Time</b>	<b>End Time</b>	<b>Total Hours</b>	<b>Remarks</b>
57	21-09-2023	12:40 PM	2:00 PM	1:20	
58		3:56 PM	5:16 PM	1:20	
59		6:12 PM	7:40 PM	1:28	
60		7:40 PM	9:10 PM	1:30	
61	22-09-2023	8:40 AM	10:10 AM	1:30	
62		10:24 AM	11:50 AM	1:26	
63		12:50 PM	2:10 PM	1:20	
64		3:56 PM	5:18 PM	1:22	
65		6:02 PM	7:10 PM	1:08	
66		7:40 PM	9:09 PM	1:29	
67		23-09-2023	8:45 AM	10:10 AM	1:25
68	10:44 AM		12:14 PM	1:30	
69	12:50 PM		2:02 PM	1:12	
70	3:56 PM		5:18 PM	1:22	
71	6:02 PM		7:32 PM	1:30	
72	7:50 PM		9:16 PM	1:26	
		<b>Total</b>		<b>95:00</b>	
					
<b>Site Incharge</b>		<b>TPIA</b>	<b>Junior Engineer</b>	<b>Assistant Engineer</b>	<b>Exe. Engineer</b>
M/S VSAIPPL-SMC JV, Ghazipur (U.P)		M/s Medhaj Techno Concept Pvt. Ltd., Ghazipur	Construction Division Office(E/M) ,U.P.Jal Nigam(Rural),Varanasi		





# Aqua Xplore

(Groundwater Assessment & Allied Services)

243/5, New Colony Jiyamau, Hazratganj, Lucknow – 226001

Mob. 9918202546 / 9889323322, Email-aquaxplorelko@gmail.com

Advisor- Dr. R. A. Yadav, ex- Manager(Groundwater), U. P. Jal Nigam

Ref 731 - J/ AX - 2023

Date 31.07.2023

## Geophysical Borehole Logging Report

Name of the site : Jayantidaspur, Block – Birno

District : Azamgarh

Date : 31.07.2023

Depth logged : 330.0 mbgl

Depth drilled : 335.0 mbgl – as reported

Logger used : Robertson make

Presence : Representative of M/S Vikran Engineering & Exim Pvt. Ltd., Ghazipur

Based on the interpretation of geophysical logs, following information may be deciphered, particularly with respect to salinity of the formation water;

Sl.No.	Depth range(mbgl)	Thickness(m)	Remarks
1	22.0–40.0	18.0	Good (1 to 5)
2	42.0–46.0	4.0	
3	54.0–58.0	4.0	
4	92.0–96.0	4.0	
5	101.0–111.0	10.0	
6	254.0–260.0	6.0	Moderate ( 6 to 10)
7	282.0–285.0	3.0	
8	288.0–292.0	4.0	
9	300.0–303.0	3.0	
10	318.0–322.0	5.0	

Note. All zones are intermixed with kankar. Quality of the formation water is deteriorating marginal to saline in between 124.0 to 226.0 mbgl. Clay layer lies in between 226.0 to 234.0 mbgl. Sl. Nos. 6 to 10 are highly kankar intermixed.

for Aqua Xplore

CC;

M/S Vikran Engineering & Exim Pvt. Ltd., Ghazipur