


COMPLETION PLAN OF TUBEWELL

NAME OF WORK :- CONSTRUCTION OF T.W. KUCH LAI G.P W/S SCHEME BLOCK GONDALMAU DISTRICT SITAPUR
 NAME OF PROGRAMME :- J J M - 2
 NAME OF CLIENT :- S.W.S.M. & U.P. JAL NIGAM (R)
 NAME OF TPI :- CEINSYS TECH LIMITED
 CONTRACT AGREEMENT :- 95/ED/2020-21 DT 23 MAR 21
 COVER AGREEMENT :- 106 /ED/21-22/ DATE 10/08/2021
 LOWERED ASSEMBLY CHART OF T.W. OF KUCH LAI G.P W/S SCHEME DISTRICT :- SITAPUR

LOWERED ASSEMBLY IN MT. 600 MM DIA BORE

Manual Strata

Sr.	From Mtr	To Mtr	Strata
1	0	3 MT	Surface Clay
2	3	20 MT	Sandy Clay
3	20	33 MT	Fine to medium Sand
4	33	42 MT	Clay Caving
5	42	49 MT	Fine to medium Sand
6	49	55 MT	Sandy Clay
7	55	62 MT	F.to.Medium.Sand
8	62	76 MT	Clay
9	76	80 MT	F.to.Medium.Sand
10	80	84 MT	Sand Clay
11	84	87 MT	F.to.Medium.Sand
12	87	95 MT	Kankar Clay
13	95	104 MT	F.to.Medium.Sand
14	104	107 MT	Clay
15	107	115 MT	F.to.Medium.Sand
16	115	126 MT	Clay Caving
17	126	133 MT	F.to.Medium.Sand
18	133	136 MT	Sand Clay
19	136	140 MT	F.to.Medium.Sand
20	140	160 MT	Kankar Clay
21	160	165 MT	F.to.Medium.Sand
22	165	165 MT	Kankar Clay



ABSTRACT

1- Required Discharge	:- 950 LPM
2- Static Water Level	:- 8 MTR
3- Type of Rig Machine	:- R.C./D.C
4- Bore Size	:- 600x450 mm dia
5- Assembly size	:- 300 x150 mm dtr
6- Total Depth of Bore	:- 165 Mtr
a- 600 mm dia o to 50	:- 50.00 m.
b- 300 mm dia 50 to 165	:- 115.00 m.
Total	:- 165.00 m.
7- Logging date	:- 30-06-2022
8- Logging Depth	:- 165.00 m.


LOGGING REPORT

Sr.	Depth Range Mbg	Thickness m.	Remarks
1	20 - 33	13.00 m	Good
2	42 - 49	7.00 m	Good
3	55 - 62	7.00 m	Good
4	76 - 80	4.00 m	Good
5	84 - 87	3.00 m	Good
6	95 - 104	9.00 m	Good
7	107 - 115	8.00 m	Good
8	126 - 133	7.00 m	Good
9	136 - 140	4.00 m	Good
10	160 - 165	5.00 m	Good

11- Detail of Tubewell Assembly

(A) 300 mm dia Housing Pipe	:- 45.00 Meter
(B) 300x150 mm dia MS Reducer	:- 0.20 Meter
(C) 150 mm dia MS Plain Pipe	:- 62.80 Meter
(D) 150 mm dia Slotted Pipe	:- 31.00 Meter
Total	:- 139.00 Meter
A G L	:- 0.50 Meter
B G L	:- 138.50 Meter
12- Date of Lowering	:- 3.7.22

PREPARED BY



RECOMMENDED BY

(VERIFIED BY)
(T.P.I.)

(Vikram Jeet)
(JE)

DIVISIONAL OFFICE (E/M)
U.P JAL NIGAM (R) LUCKNOW

(DINESH KUMAR)
(A E)

DIVISIONAL OFFICE (E/M)
U.P JAL NIGAM (R) LUCKNOW

APPROVED BY

(VISHAL ARYA)
EXECUTIVE ENGINEER

DIVISIONAL OFFICE (E/M)
U.P JAL NIGAM (R) LUCKNOW