

M/S Welspun -Kaveri JV Lower Parel (West) Mumbai

Regd. Office-BKT House / Trade World , C Wing 8th Floor,Kamala City , Senapati Bapat Marg Lower Parel (W),Mumbai 400013


Under Jal Jeevan Mission,District- Jaunpur (U.P.)

Actual TW Assembly of Nathupur TW, Block- Sirkoni, Distt. Jaunpur

PHYSICAL STRATA			
S.No.	BGL in meter		Formation
	From	to	
1	0	15	Surface Clay
2	15	27	Clay
3	27	51	Clay + Kankar
4	51	150	Fine Sand + Kankar
5	150	198	Clay
6	96	210	Fine Sand
7	198	252	Coarse Sand

Logging Report				
Date of Logging-02.07.2022				
S.N.	Depth (Mbgl)		Thickness (m)	Quality (in terms of Salinity)
	From	to		
1	30	50	20	Good
2	68	75	7	Good
3	192	214	22	Moderate to saline

Fresh and potable water will be available both in quality and quantity. The Litho samples has matched fairly with our Electrolog findings



DETAILS		
1	Date of lowering	30.04.2022
2	Depth of bore 600mm ϕ	96.00 Mbgl
3	Depth of bore 450mm ϕ	174.00 Mbgl
4	Housing pipe 300 mm ϕ	54.03 m
5	Plane pipe 200 mm ϕ	12.60 m
6	Slotted pipe 200 mm ϕ	18.02 m
7	300x200 mm ϕ Reducer	0.20 m
8	Total	84.85 m

<i>(Signature)</i> Company Repre. M/S Welspun -Kaveri JV Jaunpur (U.P.)	<i>(Signature)</i> TPIA Medhaj Techno Concept Pvt. Ltd.,Jaunpur	<i>(Signature)</i> (Aditya Singh) Junior Engineer	<i>(Signature)</i> (B.S Kushweha) Assistant Engineer	<i>(Signature)</i> (J.K Gupta) Exe. Engineer
Division Office (E&M), U.P.Jal Nigam (Rural), Varanasi				