

Completion Plan of Tube Well

Name of contractor.....

Countersigned

E. E.

YIELD TEST OF TW BY COMPRESSOR

Date of Test 20/12/2020

Static W/L 18

Taste of Water.

Discharge by V Notch		Stand Contents in PPM						Remarks
In cm	In Lpm	Start	5 Min	10 Min	15 Min	30 Min	60 Min	

Contractor

J. E.

A. E.

E. E.

YIELD TEST REPORT BY O.P. UNIT

Size of orifice

Taste of water

Date of Test 31/1/2020

Height of water column in orifice tube (c.m.)	Discharge in L.P.M.	SWL in Mts	RWL in Mts	Depression in Mts	SAND CONTENTS IN P. P. M.								Recommendations.
					Starting	5 Min.	10 Min.	15 M.	20 M.	25 M.	30 M.		
												Recommended dischargeLPM at.....mt depression. Recommended Pumping plant discharge.....Lpm.	

Contractor

J. E.

A. E.

E. E.

CHEMICAL TEST REPORT

DATE OF TEST 01/1/2020

AGENCY 120 MLD WTP LAB, UP TAL NIGAM
GHAZIABAD

Mg/Lit		mg/Lit		mg/Lit		mg/Lit	
Colour		Hardness Temp.		Chlorides	15	Remarks	
Nitrates	17.6	Copper		Nitride			
PH	7.9	Iron	BDL	Fluorides	0.20		
Total Solids		Total Alkalinity		Amonia			
Dissolved Solids	246	Sulphates	13.6				
Fixed Solids		Calcium	48				
Total Hardness (CaCO ₃)	184	Magnesium	15.5				
Permanent Hardness		Turbidity	0.7				

J. E.

A. E.

E. E.