

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.

Date: 12.5.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency: L.C. Infra Brothers Pvt. Ltd.
 Village: Bhanera Block: Khatbura
 District: Bhanera Logging Depth: 150 mtr.
 Drilling Depth: 160 mtr. Water Level: 14 mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 14	Dry Sand	
3	14 - 21	Fine Sand	
4	21 - 25	clay water	
5	25 - 33	Fine to Med Sand	medium
6	33 - 35	clay water	
7	35 - 60	medium Sand	medium
8	60 - 65	clay water	
9	65 - 70	medium Sand	medium
10	70 - 72	clay water	
11	72 - 100	medium Sand	medium
12	100 - 108	clay water	
13	108 - 140	medium Sand	medium
14	140 - 145	clay water	
15	145 - 150	medium Sand	medium
16			
17			
18			
19			
20			
21			
22			
23			

* Expected Water Bearing Zone

For Ground Water Survey Consultancy

Sant
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.