


OF THE EXECUTIVE ENGINEER TEMP. CONST.DIV.(E&M) U.P. JAL NIGAM, MAU

Final Completion Plan of Tube well Assembly Chart cum strata Chart For Masheena water supply scheme, Block- Kopaganj, District- Mau.

Detail of Strata



AGL + BGL
0.50 + 215.60 = 216.10 mts.

(Not to Scale)

Detail of Lowering

Date- 11-08-2017

1	Drilling depth	240 mts.
2	Drilling by contractor	D.C. Rig M/C
3	Total housing pipe dia 250 mm	42.10 mt.
4	Total Plain pipe dia 150 mm	137.74 mt.
5	Total Slotted pipe dia 150 mm	36.06 mt.
6	Size of assembly lowering	250mm x 150 mm x 150 mm
7	250mm x 150 mm M.S. Reducer	0.20 mt

Detail of Strata

From (m)	To (m)	Thick (m)	Desperation of the Strata
0	3.00	3.00	Surface Soil
3.00	42.00	39.00	Fine Sand
42.00	54.00	12.00	V. Fine Sand
54.00	66.00	12.00	Fine Sand
66.00	78.00	12.00	Fine Sand with Kankar
78.00	86.00	8.00	V. Fine Sand with Kankar
86.00	96.00	10.00	V.V. Fine Sand with Clay & Kankar
96.00	102.00	6.00	Kankar Clay
102.00	123.00	21.00	V. Fine Sand with Clay & Kankar
123.00	140.00	17.00	Fine Sand with Clay & Kankar
140.00	153.00	13.00	V.V. Fine Sand with Clay & Kankar
153.00	157.00	4.00	V. Fine Sand
157.00	169.00	12.00	Fine Sand
169.00	194.00	25.00	V. Fine Sand with Clay & Kankar
194.00	201.00	7.00	V. Fine Sand
201.00	220.00	19.00	Fine Sand
220.00	240.00	20.00	Clay with V. Fine Sand & Kankar

Logging Report

Date 02-08-2017

Sl. N.	Depth Range (mbgl)	Thicknees (m)	Remark
1	47.0 - 60.0	13.0	Good
2	75.0 - 85.0	10.0	Good
3	95.0 - 102.0	7.0	Good, fine sand Kankar Intermixed
4	107.0 - 112.0	5.0	Good, fine sand Kankar Intermixed
5	140.0 - 145.0	5.0	Good
6	153.0 - 168.0	15.0	Good
7	195.0 - 210.0	15.0	Good

TEST REPORT OF T.W. DEVELOPMENT BY AIR COMPRESSOR

Discharge measured by 90° "V" Notch.

Date of Test : - 29-08-2017

Date of Test :- 29-08-2017												
Sl. No.	Discharge		Air Pressure in Kg/cm ²		Depression in		Starting Sand in P.P.M.	Sand contents in P.P.M. After				Remark.
	In Inches	In L.P. M	Startin g	Runni ng	Kg/ cm ²	mts		5 Min	10 Min	15 Min	20 Min	
1	9	2107	8.00	7.40	0.60	6.00	8000	5000	3000	2000	1800	
2	8½	1831	8.00	7.50	0.50	5.00	7000	4500	2600	1500	1300	
3	8	1778	8.00	7.55	0.45	4.50	6000	4000	2000	1200	900	
Note:- Recommended for development of T/W by O.R. Unit:-												

Note- Recommended for development of T/W by O.P. Unit.

(Surendra Yadav)
J.E.

(S.N. Singh)
A.E.

YIELD TEST REPORT OF T.W BY O.P. UNIT

Discharge measured by orifice meter- 90° "V" Notch.

Date of Test : - 15-09-2017

Sl. No.	Discharge		Water level in mts.		Depre ssion in meters	Startin g	Sand contents in P.P.M. After				Remark
	In Inche s	In L.P.M	Runni ng	Static			5 Min	10 Min	15 Min	20 Min	
1	9½	2406	9.25	3.00	6.25	900	300	100	50	50	
2	8½	1831	8.25	3.00	5.25	650	250	100	50	Tr	
3	7½	1374	7.50	3.00	4.50	400	150	50	Tr	Cl	
4	6½	946	6.75	3.00	3.75	250	Tr	Cl	Cl	Cl	

Recommended discharge 800 LPM at 4.00 depression after 10 Min. in by pass.

(Surendra Yadav)
J.E.

(R.B. Ram)
A.E.

(M/s Harishchandra Sirgh)
Gorakhpur
Contractor

(Surendra Yadav)
J. E.

(S.N. Singh)

(R.B. Ram)

(N.A. Khan)
Executive Engineer