

L.C INFRA PROJECTS PVT. LTD.

Site office -House no. 110/B-9, Pardaha Mill Road (Near New public school). Mau.275101 (U.P.)

Contact No. 9935264065 E- mail I.D- lcinfra azamgarh@gmail.com, lcinfraho.jjm@gmail.com


Actual Completion Plan of Tube well Assembly Chart cum strata Chart For KUCHAHARA (TW-1) water supply scheme, Block- MOHAMMADABAD GOHANA , District- Mau. (Under – JJM/Mau)

Name of client- Executive Engineer Division office (E/M), U.P Jal Nigam (Rural) Mau.

Required Discharge:- 750 lpm

Size of T.W. assy- 300mm x 150mm dia.

(Not to Scale)

Detail of StrataAGL + BGL
0.5+135.42 =**Detail of Lowering**

Date: -

1	Drilling depth	275 m.
2	Total housing pipe dia 300 mm	42.16
3	Total plain pipe dia 150 mm	46.58
4	Total slotted pipe dia 150 mm	27.10
5	Size of assembly lowering	300 mmØ x 150mmØ
6	300 mmØ x 150mmØ M.S. Reducer	0.20 m
7	BGL	116.04
8	Total Assembly Length	116.54

Detail of Strata

From (m)	To (m)	Thick (m)	Desecration of the strata
0	22	22	S. Clay
22	26	4	M. Sand
26	32	6	sandy Clay
32	36	4	M. Sand
36	50	14	Clay with Kankar
50	56	6	M. Sand
56	60	4	sandy Clay
60	67	7	M. Sand Mix with kankar
67	73	6	sandy Clay
73	80	7	M. Sand
80	96	16	Clay with Kankar
96	100	4	M. Sand
100	103	3	M. Sand Mix with kankar
103	110	7	M. Sand
110	161	s	M. Sand
161	168	7	M. Sand
168	196	28	sandy Clay
196	199	3	M. Sand
199	200	1	CLAY

Logging Report

Date:-

10.06.2023

Sl. No.	Depth Range (mbgl)	Thickness(m)	Remarks
1	22 - 26	4.0	Good
2	32 - 36	4.0	Good
3	50 - 56	6.0	Good
4	60 - 67	7.0	Good
5	73 - 80	7.0	Good
6	96 - 100	4.0	Good
7	103 - 110	7.0	Good
8	161 - 168	7.0	Good
9	196 - 199	3.0	Good

Note. 1.Fine bands of kankar are intermixed with almost all the zones.
2.Zones Sl. No. 2 & 7 are highly intermixed with fine bands of kankar.

L C Infra Pvt Ltd

TPI

JE

AE

E.E