

GRAM :- JAL NIGAM

Phone:- 0522 - 2220173, 2220272



UTTAR PRADESH JAL NIGAM

Ref :-

Dated :-

GEOPHYSICAL LOGGING REPORT

1. Name of the site:- Chak Barbojhi, Mohamdabad
2. District:- Mau
3. Dt. Of logging:- 03.08.19
4. Drilled depth(as reported):- 280.00mbgl
5. Logged depth:- 280.0 mbgl
6. Logger no.:- AquaXplore, Lucknow
7. Concerned JE:- Er. Anuj Kumar Yadav, JE
8. Based on the geophysical log interpretation following granular zones may be deciphered, particularly with respect to salinity of the formation water.

Sl. No.	Zones (mbgl)	Thickness (mts.)	Remarks
1	34.0-67.0	33.0	Good
2	75.0-82.0	7.0	Good
3	100.0-107.0	7.0	Good
4	152.0-157.0	5.0	Good
5	202.0-207.0	5.0	Good
6	210.0-218.0	8.0	Good
7	226.0-233.0	7.0	Good
8	235.0-248.0	13.0	Good
9	264.0-268.0	4.0	Good
10	270.0-280.0	10.0	Good

All zones are kanker intermixed.

(Dr. S.Sahai)

Manager (Groundwater)

c.c.


1. EE, TCD(E/M), UP Jal Nigam, Mau for information and necessary action..

Manager (Groundwater)

OFFICE OF THE EXECUTIVE ENGINEER TEMP. CONST. DIV. (E&M) U.P. JAL NIGAM, MAU

Actual Completion Plan of Tube well Assembly Chart cum strata Chart For Chakbar Bojhi water supply scheme, Block- Muhammadabad Gohana, District- Mau, (Under Programme- S.A.G.Y.)

(Not to Scale)



वास्ते-एस० एन० ट्रेडर्स

(M/s S.N. Trade) Deoria Contractor

(Ano) Kumar Yadav J. E.

(V.K. Singh) Assistant Engineer

(J.K. Gupta) Executive Engineer