

ACTUAL ASSEMBLY AND STRATA CHART AS PER LOGGING REPORT
M/S VIKRAN ENGINEERING & EXIM PVT LTD VPRPL JV

Under Jal Jeevan Mission

Proposed Discharge from Pump

341 LPM

Name - Ahirauli W/S Scheme ,Block-Thekma, District- Azamgarh


STRATA			
S.No	BGL in Meter		Formation
	From	To	
1	0 M	6 M	Surface Clay
2	6 M	30 M	Sandy Clay
3	30 M	54 M	very Fine sand
4	54 M	95 M	Fine sand
5	95 M	165 M	Sandy Clay

Logging Report

Logging Depth in meter			131 m	
Drilling Depth in meter			165 m	
S.No	Depth Range(in Meter)		Thickness in meter	Remark
	From	To		
1	30	40	10	Good All
2	51	55	4	
3	59	66	7	
4	77	84	7	
5	86	93	7	
6				
7				
8				
9				
10				
11				
12				

Details

S.No.	Discription	Depth in meter
1	Depth of Bore 450 mm(in m)	105
2	Depth of Bore 500 mm (in m)	60
3	Drilling depth	165
4	Date of lowering	
5	Housing pipe 200 MM (in m)	54
6	Plain pipe Pipe 150 MM (in m)	24
7	Slotted pipe Pipe 150 MM (in m)	18
8	Reducer 200x150 (in m)	0.20



M/S VIKRAN ENGINEERING & EXIM PVT LTD VPRPL JV
Contractor

GYANENDRA KUMAR
J.E.

B. S. KUSHWAHA
A.E.

G. P. SINGH
E.E