

ACTUAL ASSEMBLY AND STRATA CHART AS PER LOGGING REPORT
M/S VIKRAN ENGINEERING & EXIM PVT LTD VPRPL JV

Under Jal Jeevan Mission

Proposed Discharge from Pump

1010 LPM

Name - Narwari W/S Scheme ,Block-Pawai, District- Azamgarh

STRATA


S.No	BGL in Meter		Formation
	From	To	
1	0 M	6 M	Surface Clay
2	6 M	30 M	Sandy Clay
3	30 M	63 M	very Fine sand
4	63 M	132 M	Kankar Clay
5	132 M	165 M	Sandy Clay

Logging Report

S.No	Depth Range(in Meter)		Thickness in meter	Remark
	From	To		
1	24	28	4	Good All
2	30	37	7	
3	54	61	7	
4	68	78	10	
5	80	90	10	
6				
7				
8				
9				

Details

S.No.	Discription	Depth in meter
1	Depth of Bore 450 mm(in m)	105
2	Depth of Bore 600 mm (in m)	60
3	Drilling depth	165
4	Date of lowering	
5	Housing pipe 300 MM (in m)	48
6	Plain pipe Pipe 150 MM (in m)	18
7	Slotted pipe Pipe 150 MM (in m)	24
8	Reducer 200x150 (in m)	0.25
9	Slotted pipe Pipe 300 MM (in m)	6



M/S VIKRAN ENGINEERING & EXIM PVT LTD VPRPL JV
Contractor

G.K.

GYANENDRA KUMAR
J.E.

B.S.

B. S. KUSHWAHA
A.E.

G.P.

G. P. SINGH
E.E.