

ACTUAL ASSEMBLY AND STRATA CHART AS PER LOGGING REPORT

M/s GA INFRA -BABA JV

Under Jal Jeevan Mission

Proposed Discharge from Pump

:

729

LPM

Name - Jamuawavan W/S Scheme ,Block-Thekma, District- Azamgarh

STRATA

S.No	BGL in Meter		Formation
	From	To	
1	0 M	6 M	Surface Clay
2	6 M	30 M	Sandy Clay
3	30 M	48 M	Fine sand
4	48 M	165 M	Kankar Clay
5	165 M	200 M	Sandy Clay

Logging Report

S.No	Depth Range(in Meter)		Thickness in meter	Remark
	From	To		
1	20	37	17	Good All
2	50	64	14	
3	71	84	13	
4				

Details

S.No.	Discription	Depth in meter
1	Depth of Bore 500 mm(in m)	100
2	Depth of Bore 450 mm (in m)	100
3	Drilling depth	200
4	Date of lowering	
5	Housing pipe 200 MM (in m)	66
6	Plain Pipe 150 MM (in m)	0
7	Slotted pipe Pipe 200 MM (in m)	24
8	Reducer 300x150 (in m)	0.00

G.L

200 mm

500mm

↑ ↓ .5m AGL

H
O
U
S
I
N
G

P
I
P
E

200 MM

50.50 mbgl

62.50 mbgl

71.50 mbgl

83.50 mbgl

89.50 mbgl

200 mbgl Drilling



M/S VIKRAN ENGINEERING & EXIM PVT LTD VPRPL JV
Contractor

Gy

GYANENDRA KUMAR
J.E.

B.S.

B. S. KUSHWAHA
A.E.

G.P.

G. P. SINGH
E.E