

IIIrd-Phase

48/64/18

lowering of Nankar w/s scheme Dist- Rampur Block- Milak

140/130

T.W Size - 200x150mm lowering Date - 26/10/23 discharge - 470 lpm

200mm housing pipe

150mm Plain Pipe

150mm slotted pipe

1- 6.00
2- 6.00
3- 6.00
4- 6.00
5- 6.00
6- 6.00
7- 6.00
8- 6.00

48.00M

1- 6.01
2- 6.00
3- 6.01
4- 6.02
5- 6.00
6- 6.00
7- 6.01
8- 6.01
9- 6.02
10- 6.01

60.00M

11- 6.01

66.00M

1- 6.01
2- 6.01
3- 6.00

18.00M

Logging Report As:-

81m — 83m — m. Sand — 6+1
88m — 100m — m. Sand — 6+3
110m — 113m — fine sand x
121m — 126m — m. Sand — 2

Plain Pipe

6.00 — 2.51m
3.51m — 2.30m
6.02 — 4.50m
1.52m

Slotted Pipe

6.00 — 3.00m
3.00m — 2.00m
1.00m

200 mm housing pipe — 48.00M
200x150mm Reducer — 0.20M
150mm Plain Pipe — 63.36M
150mm Slotted Pipe — 18.00M

129.56M

AGL (-) 0.30M

129.06M

