

ACTUAL ASSEMBLY AND STRATA CHART AS PER LOGGING REPORT
M/S VIKRAN ENGINEERING & EXIM PVT LTD VPRPL JV

Under Jal Jeevan Mission

Proposed Discharge from Pump

360 LPM


Name - Nadeshwar W/S Scheme ,Block-Pawai, District- Azamgarh

STRATA			
S.No	BGL in Meter		Formation
	From	To	
1	0 M	6 M	Surface Clay
2	6 M	30 M	Sandy Clay
3	30 M	54 M	Clay
4	54 M	105 M	Fine sand
5	105 M	165 M	Sandy Clay

Logging Report			

S.No	Depth Range(in Meter)		Thickness in meter	Remark
	From	To		
1	25	35	10	Good All
2	45	52	7	
3	59	66	7	
4	78	82	4	
5	85	92	7	
6	95	102	7	
7				
8				
9				
10				
11				
12				

Details		
S.No.	Discription	Depth in meter
1	Depth of Bore 450 mm (in m)	105
2	Depth of Bore 500 mm (in m)	60
3	Drilling depth	165
4	Date of lowering	
5	Housing pipe 200 MM (in m)	54
6	Plain pipe Pipe 150 MM (in m)	36
7	Slotted pipe Pipe 150 MM (in m)	18
8	Reducer 200x150 (in m)	0.20



M/S VIKRAN ENGINEERING & EXIM PVT LTD VPRPL JV
 Contractor

J.E.

A.E.

E.E.