

ACTUAL ASSEMBLY AND STRATA CHART AS PER LOGGING REPORT
M/S VIKRAN ENGINEERING & EXIM PVT LTD VPRPL JV

Under Jal Jeevan Mission

Proposed Discharge from Pump

327 LPM

Name - Senduri W/S Scheme ,Block-Thekma, District- Azamgarh

STRATA


S.No	BGL In Meter		Formation
	From	To	
1	0 M	6 M	Surface Clay
2	6 M	30 M	Sandy Clay
3	30 M	54 M	Kankar Clay
4	54 M	90 M	Fine sand
5	90 M	165 M	Sandy Clay

Logging Report

S.No	Depth Range(in Meter)		Thickness in meter	Remark
	From	To		
1	22	26	4	Good All
2	28	42	14	
3	49	61	12	
4	81	88	7	
5				
6				
7				
8				
9				
10				
11				
12				

Details

S.No.	Discription	Depth in meter
1	Depth of Bore 450 mm(in m)	105
2	Depth of Bore 500 mm (in m)	60
3	Drilling depth	165
4	Date of lowering	04-10-2023
5	Housing pipe 200 MM (in m)	54
6	Plain pipe Pipe 150 MM (in m)	28
7	Slotted pipe Pipe 150 MM (in m)	12
8	Reducer 200x150 (in m)	0.20



M/S VIKRAN ENGINEERING & EXIM PVT LTD VPRPL JV
 Contractor

J.E.

A.E.

E.E.