

Request For Inspection (RFI)

bgcc

Client:-	STATE WATER SANITATION MISSION
PMC:-	TES-WTESL(J.V.) PMC JHANSI
CONTRACTOR:-	BRIJGOPAL CONSTRUCTION COMPANY
SCHEME NAME:-	IMLOTA / TEHARKA / BARTHARI / JALAUN

Request for inspection / Approval

RFI NO. :-	
Request for Inspection on scheme work (tick as applicable)	Request Date/Time:- 25/6/22

INSTRUMENTATION	CIVIL	MECHANICAL	ELECTRICAL	Vill - Noorpur Block - Mahabaleshwar
		COMMISSIONING		


WORK PARTICULARS:-

Description of works	Comments by PMC/Client	Signature by PMC/Client	Remark
Tubewell damaged by of Unit.	OPPA Ground Lab test Certificate not provided by the E.P.C Agency		

Inspection Date:-	26/6/22	Inspection Time:-	
Request by BGCC Representative		Received by PMC Representative	
NAME	Yagah.	NAME - Vinod Agnihotri	
Signature	Yagah.	Signature - [Signature]	
Inspection Date	26/6/22	Inspection Date	26/06/22
Inspection Time	9.50 AM	Inspection Time	11:00

Encl. :-

YIELD TEST REPORT

NAME OF SCHEME		270 Tubewell Schemes		
LOCATION OF T/W		Noochipur		
REQUIRED DISCHARGE AS PER SCHEME		250.2 LPM		
DATE OF TESTING		26/6/22		
TASTE OF WATER		Sweet		
PHYSICAL WATER QUALITY		Good		
S.No.	S.W.L. IN MTR.	R.W.L. IN MTR.	DEPRESSION IN MTR.	DISCHARGE IN LPM
	20	23	3	1200
REMARKS:- O.P unit Work In Progress				
RECOMMENDED DISCHARGE			250.2 L.P.M.	
				SIGNATURE OF SWSM/JALNIGAM /PMC/TPI ENGINEER
		NAME OF SWSM/JALNIGAM /PMC/TPI ENGINEER		

YIELD TEST REPORT BT 250 P.S.I COMPRESSOR

DATE OF TEST:- 12/6/22		STATIC W/L -20		TEST OF WATER									
Village: Noodpur - Block Mahesuda													
DISCHARGE		ST.PR.	RU PR	Depre		SAND CONTENTS			10 MIN	15 MIN	20 MIN	25 MIN	REMARKS
INC	LPM	KG/CM ²	KG/CM ²	KG	MTR	START	5 MIN						
		5.80	5.30	.50	5.00	3500	3000	200	1650	800			
		8.80	8.10	.50	5.00	4100	3600	2400	1850	900			
		9.50	8.50	6.5	7.00	4500	3950	2600	2050	1100			
		11.50	11.30	8.0	8.50	4600	4200	2800	2100	1300			

Note: Recommended for further development by O.P. Unit.

Note: Recommended for further development by O.P. Unit.



[Signature]

GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Re No - 171


Date 25/11/2021

NAME OF SITE
NURPUR BLOCK- MAHEWA
JALOUN

NAME OF AGENCY
SARVODYA CONSTRUCTION
& ENGINEERING PVT LTD
DIBIYAPUR AURIYA

GEO-DRILLERS AND CONSULTANT
CONSTRUCTION OF DEEP AND SHALLOW TUBEWELL, WELL ELECTRO-
LOGGING AND DEVELOPMENT OF TUBE WELL BY AIR COMPRESSUR
RAJENDRA NAGAR MILL COLONY PUKHRAYAN KANPUR, 209111
9935299290, 8090118811, nky.phn@gmail.com





Proposed Assembly Chart Nurgur Block - Mahara

Logging report 28.11.2021

$$30.00 - 45.00 = 15.00$$

$$52.00 - 58.00 = 06.00$$

$$66.00 - 103.00 = 37.00$$

200 mm dia MSERW Plain pipe

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.
- 7.
- 8.
- 9.
- 10.

150 mm dia MSERW Plain pipe


- 1.
- 2.

150 mm dia MSERW slotting pipe


- 1.
- 2.
- 3.
- 4.

150 mm dia MSERW plain pipe cutting

$$06.00 \begin{cases} 1.25 \\ 4.75 \end{cases}$$



Assistant Engineer
Jhansi Khanda-1st
U.P. Jal Nigam, Jhansi



Request For Inspection (RFI)

bogcc

Client:-	STATE WATER SANITATION MISSION		
PMC:-	TES-WTESL(U.V.) PMC JHANSI		
CONTRACTOR:-	BRIGOPAL CONSTRUCTION COMPANY		
SCHEME NAME:-	IMLOTA / TEHARKA / BARTHARI / JALAUN		
Request for inspection / Approval			
RFI NO. :-		Request Date/Time:- 27/11/21	
Request for Inspection on scheme work (tick as applicable)			
CIVIL	MECHANICAL	ELECTRICAL	Village - Nurpur Block - Madhwa
INSTRUMENTATION	COMMISSIONING		
WORK PARTICULARS:-			
Description of works	Comments be PMC/Client / T.P.F	Signature by PMC/ Client / T.P.F	Remark
Lowering of Tubewell Assembly	Do work with Safety & Quality	<i>[Signature]</i>	
Village - Nurpur			
<i>[Signature]</i>			
Inspection Date:- 28/11/21	Inspection Time:-	Received by PMC Representative / T.P.F	
Request by BGCC Representative	NAME - Vivek Agnihotri	Signature - <i>[Signature]</i>	
NAME	Signature - <i>[Signature]</i>	Inspection Date - 28/11/21	
Signature	28/11/21	Inspection Time - 02:00 PM	
Inspection Date	10:00 AM		
Inspection Time			