

29
(53)

OFFICE OF THE EXECUTIVE ENGINEER

XIII DIVISION (E/M), U.P. JAL NIGAM, LUCKNOW

Completion plan of T/w No. of O.T.H.A.PURWA W/S Scheme District LAKIMPUR
 Type of Rig Machine Size of Bore 650 X 550 mm
 Static Water Level 3.00 metre.....

J.E. Incharge EX. NIAZ AHMAD

A.E. Incharge

Depth B.G.L. m	Strata m	Lowered Assembly	ASSEMBLY DETAILS
	2.0 SURFACE CLAY		mm dia Housing Pipe Agl.....m to.....m.....m
			mm dia Housing Pipe Bgl.....m to.....m.....m
			mm dia Reducer.....m to.....m.....m
			mm dia Pipe.....m to.....m.....m
	55.0 CLAY WITH SAND		mm dia Pipe.....m to.....m.....m
	71 FINE SAND		mm dia Pipe.....m to.....m.....m
	76 CLAY		mm dia Pipe.....m to.....m.....m
	95 FINE SAND		mm dia Pipe.....m to.....m.....m
	106 CLAY		mm dia Pipe.....m to.....m.....m
	110 FINE SAND		mm dia Pipe.....m to.....m.....m
	121 CLAY		mm dia Pipe.....m to.....m.....m
	134 FINE SAND		mm dia Pipe.....m to.....m.....m
	141 CLAY		mm dia Pipe.....m to.....m.....m
	153 FINE SAND		mm dia Pipe.....m to.....m.....m
	161 CLAY		mm dia Pipe.....m to.....m.....m
	171 CLAY		mm dia Pipe.....m to.....m.....m
	178 FINE SAND		mm dia Pipe.....m to.....m.....m
	190 FINE SAND		mm dia Pipe.....m to.....m.....m
	192 CLAY		mm dia Pipe.....m to.....m.....m
	208 FINE SAND		mm dia Pipe.....m to.....m.....m
	210 FINE SAND		mm dia Pipe.....m to.....m.....m
	227 CLAY		mm dia Pipe.....m to.....m.....m
	230.0		mm dia Pipe.....m to.....m.....m
			Total Assembly <u>213.36</u> metre

ABSTRACT

- Drilling Started on Dated.....
- Drilling Completed on Dated.....
- Drilling Depth 230.0 metre.....
- Assembly Lowered 213.36 metre.....
 Housing Pipe 55.13 mm dia 3.00 metre.....
 Reducer 0.20 mm dia x 3.00 x 2.00 mm dia.....metre.....
 Plain Pipe 141.23 mm dia 2.00 metre.....
 Slotted Pipe/Screen 24.00 mm dia 2.00 metre.....
-m³.
- Final Date of Test of T/w 7.9.15.....Recommended Discharge
5.00 LPM At 2.00 metre Depression.

Scale (H)
(V)

(NIAZ AHMAD)
J.E.

(AJAY KUMAR)
A.E.

(VIJAY KUMAR)
E.E.

Depth Logged.....m bgl

LOGGING REPORT

Date of Logging.....

Sl. No.	Depth Range m bgl	Thickness m bgl	Remarks
1.	55.00 — 70.00	15.00	Good Zone
2.	77.00 — 95.00	28.00	
3.	100.00 — 110.00	10.00	
4.	120.00 — 135.00	15.00	
5.	141.00 — 153.00	12.00	
6.	161.00 — 171.00	10.00	
7.	178.00 — 190.00	12.00	
8.	192.00 — 208.00	16.00	
9.	210.00 — 227.00	17.00	
10.			

(S)
Manager (G.W.)