

Counter Signed

R.W.L. 21.35 mt Depression 5.35 mt

(N.P. SINGH)
Junior Engineer

C.E. H. ZAIDI
Asstt. Engineer

8 Discharge Measured By

Recommended Discharge 800 LPM at 4:50 Mt. depression.

(N. P. SINGH)
Junior Engineer

CE. H. ZAIDI
Asstt. Engineer

Date of obtaining sample.....3-10-2011.....Collected by: ¹ Jamn Singh Agency ^{DUTT Lab-} C.P.V.P.J. STA

Date of Test	20-10-2011	Total Hardness	160	Sulphates	192
Colour	colourless	Temporary Hardness		Lead	
Odour	odourless	Permanent Hardness		Iron	NR
Turbidity (NTU)	Nil	Total Alkalinity (M)		Nitrates	
Ph. Value	7.0	Alkalinity (P)	220	Conductivity	
Total Solid		Calcium	60	Fluorides	1.0
Suspended Solids		Magnesium	100	Taste	sweet
Dissolved Solids	200	Chlorides	30		