

TUBE WELL DRILLING AND DEVELOPING DETAILS

Tube Well No. 2 of SUJAWAL PUR Rig No./Type Size of Bore 675/550 mm

Under SUTAWALPUR w/s scheme. Type of T.W. SLOTTED J. E. Incharge. S.P. SHARMA.

In Village.....Block.....Spining Level 7.62 m.....A. E. Incharge S.K. AGRAWAL

Tehsil..... Distt. M. KASHI RAM NAGAR Agency.....

Depth B.G.L. Meter	Stratum	Representa- tion	Executed Assembly	ASL	ASSEMBLY DETAILS
2.13	HARD CLAY + KANKAR			0.40 m	300 m.m. o Housing Pipe. 0 to 0.40 M.
6.097	M. SAND + SAND STONE				300 m.m. o Housing Pipe. 0.40 to 33.64 M.
			300 mm φ		m.m. o Housing Pipe. — to — M.
20.42	FINE TO MED. SAND			34.04 m	300 x 200 m.m. o Reducer. 33.64 to 33.94 M.
25.91	SANDY CLAY			34.30 m	200 m.m. o PLAIN Pipe. 33.94 to 46.66 M.
28.66	SANDY CLAY + KANKAR				200 m.m. o SLOTT. Pipe. 46.66 to 58.12 M.
33.54	F.S. + SAND STONE				200 m.m. o PLAIN Pipe. 58.12 to 62.03 M.
			200 mm φ		200 m.m. o SLOTT. Pipe. 62.03 to 70.26 M.
44.21	HARD CLAY + KANKAR			12.72 m	200 m.m. o PLAIN Pipe. 70.26 to 80.44 M.
46.34	SANDY CLAY + KANKAR				200 m.m. o SLOTT. Pipe. 80.44 to 84.40 M.
58.54				8.33 m	200 m.m. o PLAIN Pipe. 84.40 to 90.33 M.
61.89	CLAY + KANKAR				m.m. o Pipe to M.
71.04	F. TO M. SAND + SAND STONE			10.8 m	m.m. o Pipe to M.
76.22	HARD CLAY + KANKAR				m.m. o Pipe to M.
80.49	SANDY CLAY + KANKAR				WITH AGL Total Assembly. 90.73 M.
85.37	FINE SAND + SAND STONE				M.B. No. Page No.
102.13	HARD CLAY				
108.22	HARD CLAY				
125.00	STICKY CLAY				

As Executed

Counter Signed

YIELD TEST REPORT BY COMPRESSOR

Date 19.6.2010 Static W. L. 6.30 mt Taste of Water Sweet
R.W.L. 11.20 mt Depression 4.90 mt

Sl. No.	Discharge Measured By 90° V. Notch		Sand Contents in P. P. M.							Remarks
	In Inches	In L. P. M.	Start	5 Min.	10 Min.	15 Min.	20 Min.	25 Min.	30 Min.	
1	2	3	4	5	6	7	8	9	10	11
1	-	1500	4500	2200	1000	300	100	70	50	
	Recommendation + Development		by	O.P. Unit	13	must				

Chisti
Junior Engineer
(C.T. CHISTI)

CS.K. AGRAWAL
Asstt. Engineer
(C.S.K. AGRAWAL)

YIELD TEST REPORT

1. S. W. L. 6.50 mt
2. Date of Test 01-07-2010
3. Taste of Water SWEET
4. Size of T. Ws
5. Type of T. W.
6. Capacity of O. P. Unit
7. Length of Column Assembly
8. Discharge Measured By

Sl. No.	S. W. L. in Mts.	R. W. L. in Mts.	Depression in Mts.	Discharge in lpm	Sand Contents in P. P. M.							Remarks
					Start	5 Min.	10 Min.	15 Min.	20 Min.	25 Min.	30 Min.	
1	2	3	4	5	6	7	8	9	10	11	12	13
1	6.50	12.60	6.10	2000	700	250	100	Tr	CL	CL	CL	
2	6.50	11.10	4.60	1500	450	150	Tr	CL	CL	CL	CL	
3	6.50	10.65	4.15	1000	200	Tr	CL	CL	CL	CL	CL	

Chisti Recommended Discharge 1500 lpm at 4.60 Mt. depression.

(AUTUBUDDIN)
Junior Engineer

CS.K. AGRAWAL
Asstt. Engineer

CHEMICAL TEST REPORT

Date of obtaining sample 2.7.2010 Collected by T. CHISTI (J.E.) Agency U.P.J.N. RAM GHAT ROAD ALG.

Date of test	<u>3.7.10</u>	Total Hardness	<u>178</u>	Sulphates	<u>9.6</u>
Colour	<u>Colourless</u>	Temporary Hardness		Lead	
Odour	<u>Odourless</u>	Permanent Hardness		Iron	<u>0.07 (0.07)</u>
Turbidity (NTU)	<u>0.1</u>	Total Alkalinity (M)	<u>198</u>	Nitrates	<u>1.77</u>
Ph. Value	<u>7.75</u>	Alkalinity (P)	<u>0</u>	Conductivity	<u>404.4</u>
Total Solid		Calcium		Florides	<u>0.2</u>
Suspended Solids		Magnesium		Taste	<u>Sweet</u>
Dissolved Solids	<u>202</u>	Chlorides	<u>25</u>		

Remark Water is satisfactory