

Diagram illustrating the dimensions of the pipe and drilling assembly:

- Outer diameter: 500 mm $\varnothing$
- Inner diameter (drilling and assembly): 200 mm $\varnothing$
- Label: Drilling and assembly
- Unit: BGL in Meter

		AGL 0.50	0.00
	6.1	H.P.	5.60
	6.03	H.P.	11.63
	6.3	H.P.	17.93
	6.09	H.P.	24.02
	6.04	H.P.	30.06
	6.1	H.P.	36.16
	6.1	H.P.	42.26
	6.1	H.P.	48.36
	6.1	H.P.	54.46
	5.04	H.P.	59.50
	0.20	Reducer	59.70
	2.36	P.P.	62.06
	6.02	P.P.	68.08
	6.05	P.P.	74.13
	6.02	P.P.	80.15
	6.05	P.P.	86.20
	6.06	P.P.	92.26
	6.05	P.P.	98.31
	6.04	P.P.	104.35
	6.04	P.P.	110.39
	6.05	P.P.	116.44
	6.07	P.P.	122.51
	6.08	P.P.	128.59
	6.05	P.P.	134.64
	6.04	P.P.	140.68
	6.03	P.P.	146.71
	6.04	P.P.	152.75
	6.05	P.P.	158.80
	6.04	P.P.	164.84
	6.05	P.P.	170.89
	6.05	P.P.	176.94
	6.05	P.P.	182.99
	6.07	P.P.	189.06
	6.05	P.P.	195.11
	6.05	P.P.	201.16
	3.02	S.P.	204.18
	6.04	S.P.	210.22
	3.02	P.P.	213.24
	6.06	P.P.	219.30
	6.03	S.P.	225.33
	5.02	P.P.	230.35
	3.02	S.P.	233.37
	1.00	P.P.	234.37
	6.05	P.P.	240.42
	6.04	S.P.	246.46
	6.04	P.P.	252.50

S.No	Depth (Mbgl)		Thickness (m)	Quality (In terms of	Remarks
	From	to			
1	115	127	12	Moderate	
2	138	142	4	Good	
3	170	173	3	Good	
4	176	180	4	Good	
5	187	194	7	Good	
6	201	211	10	Good	
7	219	226	7	Good	
8	230	234	4	Good	
9	240	247	7	Good	
10	252	255	3	Good	
11	265	269	4	Good	
12	273	280	7	Good	
13	285	292	7	Good	

1	Date of lowering	04-11-2022
2	Depth of bore 500 Ø	66.00 MbgI
3	Depth of bore 450 Ø	234.00 MbgI
4	Housing Pipe 200 Ø	60.00 m
5	Plain Pipe 150 Ø	168.65 m
6	Slotted Pipe 150 Ø	24.15 m
7	200x150 mm Ø Reducer	0.20 m
	Total Lowering	253.00 M

(.....) Company Repre. M/s Afcons Infrastructure, Jaunpur (U.P.)	(.....) TPIA Medhaj Techno Concept Pvt. Ltd., Jaunpur	(Aditya Singh) Junior Engineer Division Office (E&M), U.P.Jal Nigam (Rural), Varanasi	(Sudhanshu Singh) Assistant Engineer SWSM	(J.K.Gupta) Exe. Engineer Division Office (E&M), U.P.Jal Nigam (Rural), Varanasi
---	--	---	---	--