

II CONST. DIVN. U. P. JAL NIGAM, AGRA

TUBE WELL DRILLING AND DEVELOPING DETAILS

MAJRA. DURIWALI

Tube Well No. 1 of KUCHELA Rtg No./Type R.C. Size of bore 200.0 M.M.
 Under KUCHELA Gr. of villages w/s scheme. Type of T. W. SLOTTED J. E. D.D. SARASWAT
 In Viallge. KUCHELA Block MAINPURI Water Level 5.0 M.T. A.E. R.N. SAXENA
 Tehsil. MAINPURI Distt. MAINPURI Agency MUNNA BORE WELL AGRA

Depth B. G. L. Meter	Stratum	Representation	Executed Assembly	
4.0	TOP SOIL		0.49	
10.0	SANDY CLAY		0.0	
15.0	F. SAND			
28.0	M. SAND			
48.0	CLAY + KANKER			
52.0	SANDY CLAY			
70.0	CLAY + KANKER			
95.0	M. SAND			
102.0	M. SAND			
111.0	CLAY			
116.0	SANDY CLAY			
121.0	CLAY + KANKER			
LOGGING ON - 21-07-2014 BY GLOBAL GROUND WATER CONSULTANCY, NEW DELHI 1- 10.0 TO 28.0 - GOOD 2- 70.0 TO 102.0 - GOOD				

ASSEMBLY DETAILS

200.0 mm. Dia Housing Pipe 11.4 to 14.7 M.
 200.0 mm. Dia Housing Pipe 14.7 to 27.4 M.
mm. Dia Housing Pipe to M.
mm. Dia Reducer to M.
 200.0 mm. Dia SLOTTED Pipe 27.4 to 29.2 M.
 200.0 mm. Dia PLAIN Pipe 29.2 to 102.0 M.
 200.0 mm. Dia PLAIN Pipe 102.0 to 109.08 M.
mm. Dia Pipe to M.
mm. Dia Pipe to M.
mm. Dia Pipe to M.
mm. Dia Pipe to M.
mm. Dia Pipe to M.
mm. Dia Pipe to M.
 Total Assembly 109.57 M.
 M. B. No. 784(2) Page No. 8585

ABSTRACT

1. Drilling Started.....
2. Drilling Completed 24-07-2014
3. Drilling Depth 121.0 M
4. Lowering Started 24-07-2014
5. Lowering Completed 24-07-2014
6. Assembly Lowered 109.08 M

(D.D. SARASWAT)
J. E.

(R.N. SAXENA)
A. E.

(ASHOK KUMAR AGARWAL)
E. E.

Date...30-08-2014...Static W/L...05.0 MT...Tast of Water...POTABLE

Date...30-08-2014...Static W/L...05.0 MT...Tast of Water...POTABLE

1427/TESTING/184/DATED 20-08-2014

YIELD TEST REPORT BY O. P. UNIT
DATE OF TEST - 30-09-2014
1807/TESTING/196 PATEA- 01-10-2014

(R.K. SAXENA)
A. E.

DATE OF TEST - 30-09-2014

1607/TESTING/196 PATED-01-10-2014

Recommended Discharge.....200..... L. P. M. At 4.50.....M. Depression

(ARUN KUMAR)
E. E.

1661/TESTING/201/17-10-14

Date of obtaining Sample..... 15-10-14 Collected by..... Agency..... M/s. Mughal Exports Pvt. Ltd.

Remark :- SATISFACTORY

Executive Engineer