


II CONST. DIVN. U. P. JAL NIGAM, AGRA

TUBE WELL DRILLING AND DEVELOPING DETAILS

LOCATION: RATHERA (NEAR PRIMARY SCHOOL)

Tube Well No.....of RATHERA.....Rig No./Type.....D.C.....Size of bore 600 mm ϕ
 Under RATHERA.....MAIN PURI
 Gr. of villages w/s scheme. Type of T. W. SLOTTED.....J. ERAMESH CHANDRA
 In Viallge. RATHERA.....Block.....Water Level 97.00 Mtr.....A. ERAHUL DIWAKAR
 Tehsil.....Distt. MAIN PURI.....Agency M/s. MUNNA BOREWELL, AGRA

Depth B. G. L. Meter	Stratum	Representation	Executed Assembly	ASSEMBLY DETAILS
0.00-3.00	SURFACE SOIL			300 mm. Dia Housing Pipe AGL to 9.50 M.
3.00-12.00	SANDY CLAY			mm. Dia Housing Pipe 9.50 to 47.59 M.
12.00-20.00	FINE SAND			mm. Dia Housing Pipe.....to.....M.
20.00-45.00	SANDY CLAY			300 x 200 mm. Dia Reducer 47.59 to 47.74 M.
45.00-56.00	FINE SAND			200 mm. Dia PLAIN Pipe 47.74 to 49.74 M.
56.00-73.00	CLAY KANKAR			200 mm. Dia SLOTTED Pipe 49.74 to 55.77 M.
73.00-86.00	FINE TO MED. SAND			200 mm. Dia PLAIN Pipe 55.77 to 73.77 M.
86.00-104.00	MED. SAND			200 mm. Dia SLOTTED Pipe 73.77 to 79.79 M.
104.00-110.00	SANDY CLAY			200 mm. Dia PLAIN Pipe 79.79 to 83.79 M.
110.00-115.00	FINE SAND			200 mm. Dia SLOTTED Pipe 83.79 to 101.83 M.
115.00-121.00	CLAY KANKAR			200 mm. Dia PLAIN Pipe 101.83 to 107.83 M.
E-LOGGING ON Dt. 12.11.2016				mm. Dia.....Pipe.....to.....M
12.00 M. to 20.00 M BGL	GOOD			mm. Dia.....Pipe.....to.....M
45.00 M. to 56.00 M BGL	GOOD			mm. Dia.....Pipe.....to.....M
73.00 M. to 86.00 M BGL	GOOD			
86.00 M. to 104.00 M BGL	GOOD			
110.00 M. to 115.00 M BGL	MAR. SALINE			



ASSEMBLY DETAILS

300 mm. Dia Housing Pipe AGL to 9.50 M.

.....mm. Dia Housing Pipe 9.50 to 47.59 M.

.....mm. Dia Housing Pipe.....to.....M.

300 x 200 mm. Dia Reducer 47.59 to 47.74 M.

200 mm. Dia PLAIN Pipe 47.74 to 49.74 M.

200 mm. Dia SLOTTED Pipe 49.74 to 55.77 M.

200 mm. Dia PLAIN Pipe 55.77 to 73.77 M.

200 mm. Dia SLOTTED Pipe 73.77 to 79.79 M.

200 mm. Dia PLAIN Pipe 79.79 to 83.79 M.

200 mm. Dia SLOTTED Pipe 83.79 to 101.83 M.

200 mm. Dia PLAIN Pipe 101.83 to 107.83 M.

.....mm. Dia.....Pipe.....to.....M

.....mm. Dia.....Pipe.....to.....M

.....mm. Dia.....Pipe.....to.....M

Total Assembly 108.33 Mtr.

M. B. No. 042 (L) Page No 65, 66.

ABSTRACT

1. Drilling Started.....01.11.2016.....
2. Drilling Completed.....11.11.2016.....
3. Drilling Depth.....121.00.....M
4. Lowering Started.....19.11.2016.....
5. Lowering Completed.....19.11.2016.....
6. Assembly Lowered.....107.83.....M

J. E.

A. E.

E. E.

TEST REPORT BY COMPRESSOR 250 PSI 650 CFM

Date: 07.12.2016..... Static W/L..... 8.00 Mtr..... Test of Water..... POTABLE

Discharge

2263/Testing/448 Dt. 16.12.2016
Sand Contents

In L. P. M.

Start

5min

10min

15min

20min

25min

30min

Remark

600

6000

4600

3800

2800

1900

1000

600

-

(Ramesh Chandra)
J.E.

YIELD TEST REPORT BY O. P. UNIT

(Rahul Diwakar)
A. E.

Discharge in L. P. M.	Starting W. L.	Running W. L.	Depression Meter	2263/Testing/459 Dt. 16.12.2016 SAND CONTENTS IN P. P. M.							Remarks
				Start	5 min.	10 Min.	15 min.	20 min.	25 min.	30 min.	
1300	8.50	14.50	6.00	600	300	100	Tr.	CL.	CL.	CL.	
1000	8.50	13.00	4.50	200	100	Tr.	CL.	CL.	CL.	CL.	
800	8.50	12.30	3.80	150	Tr.	CL.	CL.	CL.	CL.	CL.	

Recommended Discharge..... 1000..... L. P. M. At..... 4.50..... M. Depression
Seen

(Ramesh Chandra)
J.E.

(Rahul Diwakar)
A. E.

(Shekhar Dast)
E. E.

CHEMICAL TEST RESULTS

Date of obtaining Sample..... Collected by..... Agency.....

Date of Test	Total Hardness	Sulphates
Colour	Temporay hardness	Phosphate
Odour	Permanent Hardness	Ammonia
Turbidity	Total Alkalinity (M)	Nitrates
Ph Value	Alkalinity (P)	Flouride
Total Solids	Calcium	
Suspended Solids	Magnicium	
Dissolved Solids	Chlorids	

Remark :-

Draughts Man

Junior Engineer

Assistant Engineer

Executive Engineer

