


(6)

Actual strata chart & Assembly lowered of chart for dist. Janda Giran Nara Nirmal Yojana.



Required discharge: ✓
 Bore Size: 600 mm
 Assembly Size: 250 x 150
 Drilling depth: 150 m
 Logging depth: 145 m
 Date of logging: 30/10/18
 Date of lowering: 01/01/18

Sr No	Range in meter	Thickness in meter	Remarks
1	48-87	42.0	
2	92-98	6.0	(normal)
3	100-119	19.0	

1. Total lowering: 130 m

ACIL

BCIL

2. 250 mm φ housing pipe

3. 150 mm φ plain pipe

4. 150 mm φ slot pipe

5. 250 x 150 mm reducer

6. Ball Plug

Signature

Signature

Signature

Signature

Aqua Xploretech Welfare Society

(Groundwater Assessment & Allied Services)
243/5, New Colony Jiyamau, Hazratganj, Lucknow-226001

Ref 1230 - C / AXWS - 2015

Date 30.12.2015

Geophysical Borehole Logging Report

Name of the site : Chetpur
District : Gonda
Date : 30.12.2015
Depth logged : 145.0 mbgl
Depth drilled : 150.0 mbgl
Logger used : AXWS

Based on the interpretation of geophysical logs, following information may be deciphered, particularly with respect to salinity of the formation water.

Sl.No.	Depth range(mbgl)	Thickness(m)	Remarks
1	45.0-----87.0	42.0	Good all
2	92.0-----98.0	6.0	
3	100.0-----119.0	19.0	

Note. No suitable zones were encountered below 119.0 mbgl till depth logged.



for Aqua Xploretech

Welfare Society

To

M/S Shri Sai Construction Company

50/4, Wazir Hasan Road, Lucknow