


COMPLETION PLAN OF TUBEWELL

NAME OF WORK :- CONSTRUCTION OF T.W. SAHROI KALIKA G.P W/S SCHEME BLOCK AILIYA DISTRICT SITAPUR
 NAME OF PROGRAMME :- J J M - 2
 NAME OF CLIENT :- S.W.S.M. & U.P. JAL NIGAM (R)
 NAME OF TPI :- CEINSYS TECH LIMITED
 CONTRACT AGREEMENT :- 95/ED/2020-21 DT 23 MAR 21
 COVER AGREEMENT :- 106 /ED/21-22.....DATED 10/08/2021
 LOWERED ASSEMBLY CHART OF T.W. OF SAHROI KALIKA G.P W/S SCHEME DISTRICT :- SITAPUR

LOWERED ASSEMBLY IN MT. 500 MM DIA BORE



ABSTRACT	
1- Required Discharge	:- 330 LPM
2- Static Water Level	:- 10 MTR
3- Type of Rig Machine	:- R.C./D.C
4- Bore Size	:- 500x450 mm dia
5- Assembly size	:- 200x150 mm dtr
6- Total Depth of Bore	:- 165 Mtr
a- 500 mm dia o to 50	:- 50.00 m.
b- 200 mm dia 50 to 165	:- 115.00 m.
Total	:- 165.00 m.
7- Logging date	:- 08-12-2022
8- Logging Depth	:- 168.00 m.

LOGGING REPORT				
Sr.	Depth	Range	Thickness	Remarks
		Mbgl	m.	
1	21	- 28	7.00 m	Good
2	37	- 47	10.00 m	Good
3	50	- 57	7.00 m	Good
4	67	- 71	4.00 m	Good
5	77	- 81	4.00 m	Good
6	98	- 110	12.00 m	Good
7	115	- 122	7.00 m	Good
8	127	- 134	7.00 m	Good
9	159	- 166	7.00 m	Good
10				
11				

11- Detail of Tubewell Assembly	
(A) 200 mm dia Housing Pipe	:- 45.00 Meter
(B) 200x150 mm dia MS Reducer	:- 0.20 Meter
(C) 150 mm dia MS Plain Pipe	:- 82.80 Meter
(D) 150 mm dia Slotted Pipe	:- 12.00 Meter
Total	:- 140.00 Meter
A G L	:- 0.50 Meter
B G L	:- 139.50 Meter
12- Date of Lowering	08-12-2022

PREPARED BY

(P. M.)

LARSEN AND TOUBRO
LIMITED SITAPUR

RECOMMENDED BY

(VIKRAM JEET)
(J E)

DIVISION OFFICE (E/M)
U.P JAL NIGAM (R) LUCKNOW

APPROVED BY

(SHRI RAM GUPTA)

EXECUTIVE ENGINEER
DIVISION OFFICE (E/M)
U.P JAL NIGAM (R) LUCKNOW

(RAJENDRA KUMAR)
(A E)

DIVISION OFFICE (E/M)
U.P JAL NIGAM (R) LUCKNOW

(VERIFIED BY)
(T. P. I)