

07

FEBRUARY

Monday

2022

Week 07 • (038-327)

Week	M	T	W	T	F	S	S	Week	M	T	W	T	F	S	S
01						1	2	06							
02	3	4	5	6	7	8	9	07	1	2	3	4	5	6	7
03	10	11	12	13	14	15	16	08	8	9	10	11	12	13	14
04	17	18	19	20	21	22	23	09	15	16	17	18	19	20	21
05	24	25	26	27	28	29	30	10	22	23	24	25	26	27	28
06	31							11	29	30					

Lowering of T.W Assembly at Kichhaura u/s Scheme, Deoria
 Drilling Lowering - 132/120m T.W Assembly size - 200X150mm
 Bore size - 550 X 500mm Recommended Discharge - 500 LPM
 Logging rate - 0.5-0.8-2021 P.O.L

Logging Report

1. 25-31 — 06m	6.06	0.50m
2. 33-37 — 04m	6.04	
3. 41-43 — 02m	6.03	
4. 55-62 — 07m	6.06	36.24m
5. 67-71 — 10m	6.03	
6. 87-90 — 03m	6.02	35.70m
7. 95-108 — 13m		0.15 76.89m
8. 118-124 — 06m	6.01	

Strata as per actual

0 — 5m clay	6.01	31.45m
05 — 12m F to m sand	6.01	
12 — 30m clay	1.60	
30 — 38m F to m sand	6.00	67.54m
38 — 41m clay	3.00	9.00m
41 — 50m m sand	6.02	76.54m
50 — 65m clay	6.02	24.07m
65 — 78m F to m sand	6.02	
78 — 86m clay	6.01	100.61m
86 — 91m m sand	6.00	106.61m
91 — 94m clay	6.01	112.62m
94 — 110m F to m sand		0.50m
110 — 117m F sand		Total = 113.12m
117 — 125m F to m sand		
125 — 132m clay		