

Ref : MTL/WL/22-23/175

Date 21.03.2023

REPORT ON GEO-PHYSICAL RESISTIVITY LOGGING OF BOREHOLE

A deep borehole was drilled by working agency M/s. VTL- GAJA (JV) as a part of their scope of work of development of Tubewell under Jal Jeevan Mission Project of SWSM, MTL conducted a Geophysical Continuous logging in the above borehole.

Village Name	AHURI
Block	TILOI
District	AMETHI, U.P.
Logged Depth	164.58 Mtr BGL
Type of Log	Continuous well logger (SP, N16 (SN), N64 (LN) & LAT)
Machine Used	IGIS
Logging Date	20.03.2023


The following aquifer zones have been deciphered with the help of logging machine.

Sr. No.	Depth Range (mtr BGL)	Thickness (mtr)	Expected Quality
1	15 – 22	7	Good
2	39 – 43	4	Good
3	47 – 54	7	Good

Rw – 17 Ohm mtr and Rm – 17.5 Ohm mtr

Note: Below 64 MBGL the quality of the formation water is marginal to saline till log depth.

— Logging performed as per SWSM guidelines
 — Groundwater quality interpreted by firm as per their calibration

For Geo-Technical Consultant,

 Authorised Signatory

Gsh
 21/03/23