


Actual Assembly chart of Shivpura Th Dist Bahraich under QPV Programme

Dr. H. L. Choudhary



1. Required Discharge 500m
2. Bore size 600 x 500mm
3. Assembly Size 250 x 150mm
4. Depth of drill 135m
5. Depth of Logging 122m
6. Date of Logging 27-10-15

Detail of Logging

Sr No	Zone Range	Thickness	Remarks
1	50-57	7.00	
2	60-75	15.00	
3	78-93	15.00	
4	97-101	4.00	Good
5	105-112	7.00	
6	117-121	4.00	
7	125-135	10.00	

By Dr. R. A. Yadav
Manager G.W.

Sr No	Zone Range	Thickness	Remarks
1	50-57	7.00	
2	60-75	15.00	
3	78-93	15.00	
4	97-101	4.00	Good
5	105-112	7.00	
6	117-121	4.00	
7	125-135	10.00	

For M/s Balajee Enterprises
श्री जी एम
Proprietor

En. R. S. Prasad J.E
En. S. K. Kandhari AC
En. R. K. Singh EE