


DARA Eco-Protection (JV)



Strata Chart & Actual T/W Assembly of Size 300x150 mm Ø of G.P-Budantpur & Patoha Kot. Block- Tulsipur.



1	Bore Size	=	600X450 MM
2	Assembly Size	=	300x150 MM
3	Drilling Depth	=	265 m
4	Logging Depth	=	265 m
5	Date of Logging	=	02-04-2024
6	Required Discharge	=	860 LPM

Logging Report			
S.N.	Depth Range (M bgl)	Thickness (Mtr)	Remarks
1	Sep-30	21	GOOD ALL
2	38 - 47	9	
3	55 - 76	21	
4	80 - 89	9	
5	98 - 110	12	
6	115 - 133	18	
7	140 - 146	6	
8	154 - 160	6	
9	165 - 180	15	
10	200 - 236	36	
11	244 - 250	6	

S.N.	Description	Length (Mtr)	Remarks
1	200 MM Ø HOUSING PIPE	60.98	
2	150 MM Ø PLAIN PIPE	140.83	
3	150 MM Ø SLOTTED PIPE	38.00	
4	200X150 MM REDUCER	0.20	
TOTAL ASSEMBLY		240.01	
LESS A.G.L		0.50	
BGL		239.51	

Prepared by

Checked by

Recommended by

Approved by

DARA Eco-Protection (JV)
Contractor

Er. Abhay Tiwari
Junior Engineer

Er. Sudheer pandey
Assistant Engineer

Er. Suleman Khan
Executive Engineer

Divisional office U.P Jal Nigam (Rural) Gonda.U.P-271001.