


Proposed The Assembly chart of Rammadai w/s scheme block suretying distt. Barabanki



- 1- Discharge 540LPM
- 2- Motor HP 10HP
- 3- Assembly size 200x150mm
- 4- Bore ϕ 500 x 450mm
- 5- Logging Report dt- 25-2-23

- 1- 45-51=6
- 2- 57-63=6-6
- 3- 65-68=3
- 4- 93-100=7-6
- 5- 107-120=13-6
- 6- 123-129=6-6
- 7- 136-139=3
- 8- 145-151=6

M/s MahalaxmiTubewell

Pukhrayan Kanpur 9935299290

Geophysical Well Logging Report

Ref No -2206

Date-25/02/2023

Site Location : - Rammadai Suratganj Barabanki

District : - Barabanki

Logged Depth : - 165 MBGL 158

Date of Logging : - 25/02/2023

Types of Log : - S.P & N16, N64, LAT

Logger used : - GIS

The following permeable granular zones have been deciphered with the help of Electrical Logger.

Sr No	Depth Range From M.B.G.L	Depth Range M.B.G.L.	Thickness Mtr.	Inferred Lithology	Quality of G.W.
01	45	51	06	Fine to Medium sand	Good
02	57	63	06		
03	65	68	03		
04	93	100	07		
05	107	120	13		
06	123	129	06		
07	136	139	03		
08	145	151	06		

Note-All zones are intermixed with fine bands of kankar.

Logging performed as per SWSM guidelines.
Groundwater quality interpreted by firm as per their logger calibration.

GIS
25/02/23

M/s MahalaxmiTubewell