

# **GEO-PHYSICAL WELL ELECTROLOGGING REPORT**

Re No – 18/04

Date- 27/04/2025

## **NAME OF SITE**

CHILMAPUR

SAKIT

ETAH

## **NAME OF AGENCY**

M/S BRAJ GOPAL CONSTRUCTION  
HATHRAS

## **M/S MAHALAXMI TUBE WELL**

CONSTRUCTION OF DEEP AND SHALLOW TUBEWELL, WELL ELECTRO- LOGGING  
AND DEVELOPMENT OF TUBE WELL BY AIR COMPRESSUR

RAJENDRA NAGAR MILL COLONY PUKHRAYAN KANPUR, 209111 9935299290,  
8090118811, mahalaxmitubewell@gmail.com

**ISO; 9001:2015**

# M/s Mahalaxmi Tube well



Rajnendra Nagar Pukhrayan Kanpur  
9935299290mahalaxmitubewell@gmail.com

## Geophysical Well Logging Report

Ref No – 18/04

Date -27/04/2025

Site Location : - Chilmapur Sakit Etah

District : - Etah

Logged Depth : - 117 M BGL

Date of Logging : - 27/04/2025

Types of Log : - S.P& N16, N-64 LAT

Logger used : - IGIS

The following permeable granular zones have been deciphered with the help of Electrical Logger

Sr NO	Depth Range From M.B.G.L	Depth Range M.B.G.L.	Thickness Mtr.	Inferred Lithology	Quality of G.W.
01	0	15	15	Surface Clay with Kankar	
02	15	23	08	Clay	
03	23	27	04	Fine to medium Sand	Good
04	27	31	04	Clay	
05	31	37	06	Fine to medium Sand	Good
06	37	41	04	Clay	
07	41	44	03	Fine to medium Sand	Good
08	44	56	12	Clay	
09	56	65	09	Fine to medium Sand	Good
10	65	117	52	Clay Kankar	

Note- All zones are intermixed with fine bands of kankar. No Suitable zones encountered below 71 Mbgl to till logged and quality of the formation water is poor.

M/s Mahalaxmi Tube Well

