

7

Project Name : Implementation of various rural water supply project including O&M for 10 Year for Panerua Village, Block-Amasuli, District-Fatehpur of the State of Uttar Pradesh (under Jal Jeevan Mission) Phase-III
Actual Lowering Chart of Vill. Panerua 150*200 Discharge = 550 LPM


Gram Panchayat : Panerua
Block : Amasuli
District : Fatehpur

Sr No.		
1	TW Const. By	M/s PMPL-BRCCPL(V)
2	Size of Borewell	150*200
3	Date of Logging	18-04-2023
4	Date of Lowering	23-04-2023

Abstract of Pipe				
Sr. No.	Discription	UOM	Item	Qty
1	200 MM	MTR	PLAIN PIPE	66.17
2	150x200 MM	MTR	Reducer	0.15
3	150 MM	MTR	PLAIN PIPE	55.17
4	150 MM	MTR	SLOTTED PIPE	22.02
Total Length				143.51

Logging Report			
Sr. No.	Discription	Thickness(M)	Quality of G.W
1	29-36	7	ALL GOOD
2	47-55	8	
3	90-96	6	
4	98-105	7	
5	113-119	6	
6	126-129	3	
7	132-137	5	

Note :- Almost all Zones are intermixed with fine bands of kankar.



Prady
S.O. (ME) Engineer

Abek
Junior Engineer

[Signature]
Assistant Engineer

[Signature]
Executive Engineer

M/s Mahalaxmi Tube well

Rajnendra Nagar Pukhrayan Kanpur 9935299290

Geophysical Well Logging Report

Ref No -04/190

Date -18/04/2023

Site Location : - Nareni Panerua Amauli Fatehpur

District : - Fatehpur

Logged Depth : - 157 ~~M~~ BGL

Date of Logging : - 18/04/2023

Types of Log : - S.P&N16, N-64 LAT

Logger used : - ~~IGIS~~

The following permeable granular zones have been deciphered with the help of Electrical Logger

Sr NO	Depth Range From M.B.G.L	Depth Range M.B.G.L.	Thickness Mtr.	Inferred Lithology	Quality of G.W.
01	29	36	07	Fine to medium Sand	All Good
02	47	55	08		
03	90	96	06		
04	98	105	07		
05	113	119	06		
06	126	129	03		
07	132	137	05		

Note- All zones are highly intermixed with fine bands of kankar.

Sr NO 1-30-34 (4m)

Sr NO 3-91-95 (4m)

Sr NO 5-113-117 (4m) M/s Mahalaxmi Tube Well

- Logging performed as per SWSM guidelines.

- Groundwater quality interpreted by firm as per their logger calibration

G. Sh
19/04/23