

GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Re No – 05/232

Date- 21/05/2023

NAME OF SITE
SHEKHPUR GUDHA
MAHEVA
JALAUN

M/S MAHALAXMI TUBE WELL
CONSTRUCTION OF DEEP AND SHALLOW TUBEWELL, WELL ELECTRO-
LOGGING AND DEVELOPMENT OF TUBE WELL BY AIR COMPRESSUR
RAJENDRA NAGAR MILL COLONY PUKHRAYAN KANPUR, 209111
9935299290, 8090118811, mahalaxmitubewell@gmail.com
ISO; 9001:2015

M/S MAHALAXMI TUBE WELL

Geophysical Well Logging Report

Ref No – 05/232

Date- 21/05/2023

Site Location : - Shekhpurgudha Maheva Jalauan

District : - Jalaun

Logged Depth : - 96 Mbgl

Date of Logging : -21/05/23


Types of Log : - S.P & Resistivity

Logger used : - IGIS


The following permeable granular zones have been deciphered with the help of Electrical Logger.

Depth Range From M.B.G.L	Depth Range M.B.G.L.	Thickness Mtrs.	Inferred Lithology	Quality of G.W.
0	58	58	Surface Clay Kankar	
58	63	05	Fine to medium sand	Good
65	69	04		
72	92	20		

Note - All zones intermixed with fine bands of kankar.


M/s Mahalaxmi Tubewell


MEMORANDUM
FOR THE RECORD



PROPOSED ASSEMBLY CHART OF TUBEWELL

NAME OF SCHEME :- SHEKHPUR GURA GP WSS
 NAME OF SITE :- SHEKHPUR GURA
 BLOCK :- MAHEWA
 NAME OF COMPANY :- BGCCPL
 TYPE OG RIG M/C :- D.C.

DISTRICT :- JALAUN (ORAI)
 SIZE OF BORE :- 500 X 450 MM
 SIZE OF ASSEMBLY :- 200 X 150 MM
 SPRING WATER LEVEL :-MTR



LOGGING DATE: - 21/05/2023			
LPM REQUIRED: -400			
Sr.N	Depth Range (M)	Thickness (M)	Remark
1			GOOD
2	58 TO 63	5	
3	65 TO 69	4	
4	72 TO 92	20	
5			
6			
7			
8			
9			
10			

Abstract

1. Drilling completed on dt.....
2. Lowering on Dt.....
3. Drilling DepthM
4. 200 mm Dia Housing pipe.....M
5. 200x150 mm Dia reducer...0.25.M
6. 150 mm Dia Plain pipe.....M
7. 150 mm Dia Slotted Pipe.....M
8. Total Assy. Length.....M
9. Pea Gravel Quality.....

Proposed By

RECOMMENDED BY

APPROVED BY



Scanned with OKEN Scanner